Appendix 9.5

BART Analysis for KCP&L - La Cygne Units 1 and 2

CALPUFF BART MODELING PROTOCOL • KANSAS CITY POWER & LIGHT

LA CYGNE GENERATING STATION

VERSION 0

Prepared by:

Kasi Dubbs • Senior Consultant Mary Pham • Consultant

TRINITY CONSULTANTS
25055 West Valley Parkway
Suite 101
Olathe, Kansas 66061
(913) 390-9700

November 2006

Project 061701.0125



1.		Introduction	5
	1.1	BACKGROUND	5
	1.2	LOCATION OF SOURCES AND RELEVANT CLASS I AREAS	
	1.3	Objective	6
2.		CALPUFF MODEL SYSTEM	7
	2.1	MODEL VERSIONS	
	2.2	Modeling Domain	
3.		CALMET	9
	3.1	GEOPHYSICAL DATA	
		3.1.1 TERRAIN DATA	9
		3.1.2 LAND USE DATA	10
		3.1.3 COMPILING TERRAIN AND LAND USE DATA	11
	3.2	METEOROLOGICAL DATA	11
		3.2.1 MESOSCALE MODEL METEOROLOGICAL DATA	11
		3.2.2 SURFACE METEOROLOGICAL DATA	12
		3.2.3 PRECIPITATION METEOROLOGICAL DATA	13
	3.3	SUMMARY OF CALMET CONTROL PARAMETERS	14
4.		CALPUFF	21
	4.1	SOURCE EMISSIONS DATA	21
		4.1.1 SO ₂ , NO _x , AND PM ₁₀ EMISSIONS	21
		4.1.2 SPECIATED PM ₁₀ EMISSIONS	21
	4.2	GEP STACK HEIGHT	22
	4.3	CLASS I AREA RECEPTORS	24
	4.4	BACKGROUND OZONE	27
	4.5	BACKGROUND AMMONIA	28
	4.6	SUMMARY OF CALPUFF CONTROL PARAMETERS	28
5.		CALPOST	43
	5.1	LIGHT EXTINCTION ALGORITHM	43
	5.2	CALPOST PROCESSING METHOD	43
	5.3	NATURAL BACKGROUND	44
	5.4	SUMMARY OF CALPOST CONTROL PARAMETERS	44
	5.5	EVALUATING BART	49
AP	PENDI	ıx A	•••••
AP	PENDI	ıx B	•••••
АP	PENDI	ıx C	

LIST OF TABLES

TABLE 1-1. DISTANCE TO CLASS I AREAS	6
TABLE 2-1. CALPUFF MODELING SYSTEM VERSIONS	7
TABLE 3-1. SUMMARY OF CALMET INPUTS	15
TABLE 4-1. SO ₂ , NO _X AND PM ₁₀ EMISSIONS	21
TABLE 4-2. HOURLY PM ₁₀ SPECIATED EMISSIONS	22
TABLE 4-3. SUMMARY OF STACK PARAMETERS	23
TABLE 4-4. SUMMARY OF OZONE MONITORS	27
TABLE 4-5. SUMMARY OF CALPUFF INPUTS	28
TABLE 5-1. MONTHLY HUMIDITY FACTORS	43
TABLE 5-2. DEFAULT AVERAGE ANNUAL NATURAL BACKGROUND LEVELS	44
TABLE 5-3. SUMMARY OF CALPOST INPUTS	44
TABLE A-1. LAND USE DATA USED IN ANALYSIS	2
TABLE A-2. TERRAIN DATA USED IN ANALYSIS	2
TABLE B-1. LIST OF SURFACE METEOROLOGCAL STATIONS	1
TABLE B-2 LIST OF PRECIPITATION METFOROLOGICAL STATIONS	2

FIGURE 1-1. LOCATION OF KCP&L LA CYGNE GENERATING STATION AND NEARBY CLASS I AREA	1S6
Figure 2-1. Proposed Modeling Domain	8
FIGURE 3-1. PLOT OF LAND ELEVATION USING USGS TERRAIN DATA	10
FIGURE 3-2. PLOT OF LAND USE USING USGS LULC DATA	11
FIGURE 3-3. PLOT OF SURFACE STATIONS	13
FIGURE 3-4. PLOT OF PRECIPITATION METOROLOGICAL STATIONS	14
FIGURE 4-1. LA CYGNE STACK AND BUILDING LOCATIONS	23
Figure 4-2. Hercules-Glades Wilderness Receptor Locations	24
FIGURE 4-3. WICHITA MOUNTAINS RECEPTOR LOCATIONS	25
FIGURE 4-4. UPPER BUFFALO RECEPTOR LOCATIONS	26
FIGURE 4-5. CANEY CREEK RECEPTOR LOCATIONS	26
FIGURE 4-6 MINGO RECEPTOR LOCATIONS	27

1.1 BACKGROUND

On July 1, 1999, the U.S. Environmental Protection Agency (EPA) published the final Regional Haze Rule (RHR). The objective of the RHR is to improve visibility in 156 specific areas across with United States, known as Class I areas. The Clean Air Act defines Class I areas as certain national parks (over 6000 acres), wilderness areas (over 5000 acres), national memorial parks (over 5000 acres), and international parks that were in existence on August 7, 1977.

On July 6, 2005, the EPA published amendments to its 1999 RHR, often called the Best Available Retrofit Technology (BART) rule, which included guidance for making source-specific BART determinations. The BART rule defines BART-eligible sources as sources that meet the following criteria:

- (1) Have potential emissions of at least 250 tons per year of a visibility-impairing pollutant,
- (2) Began operation between August 7, 1962 and August 7, 1977, and
- (3) Are listed as one of the 26 listed source categories in the guidance.

A BART-eligible source is not automatically subject to BART. Rather, BART-eligible sources are subject-to-BART if the sources are "reasonably anticipated to cause or contribute to visibility impairment in any federal mandatory Class I area." EPA has determined that sources are reasonably anticipated to cause or contribute to visibility impairment if the visibility impacts from a source are greater than 0.5 deciviews (dv) when compared against a natural background.

Air quality modeling is the tool that is used to determine a source's visibility impacts. States have the authority to exempt certain BART-eligible sources from installing BART controls if the results of the modeling demonstrate that the source cannot reasonably be anticipated to cause or contribute to visibility impairment in a Class I area. Further, states also have the authority to define the modeling procedures for conducting modeling related to making BART determinations.

1.2 LOCATION OF SOURCES AND RELEVANT CLASS I AREAS

Kansas City Power & Light (KCP&L) has identified the following sources that meet the three criteria for being BART-eligible sources:

- ▲ La Cygne Generating Station Boiler Unit 1
- ▲ La Cygne Generating Station Boiler Unit 2

Table 1-1 provides a summary of the distances from the La Cygne Generating Station to nearby Class I areas.

TABLE 1-1. DISTANCE TO CLASS I AREAS

	Distance to Class I Area (km)								
Source	Wichita Mountains	Hercules- Glades	Upper Buffalo	Caney Creek	Mingo				
La Cygne	533.4	233.6	291.5	437.8	416.4				

Figure 1-1 provides a plot of the location of the La Cygne Generating Station with respect to the listed Class I areas.

FIGURE 1-1. LOCATION OF KCP&L LA CYGNE GENERATING STATION AND NEARBY CLASS I AREAS



1.3 OBJECTIVE

The objective of this document is to provide a protocol summarizing the modeling methods and procedures that KCP&L will follow as we evaluate the visibility impacts attributable to La Cygne Unit 1 and La Cygne Unit 2 in the Class I areas listed in Table 1-1. Initially, KCP&L will use the methods in this protocol to determine the visibility impacts based on the existing emission rates and exhaust characteristics for the units (See Section 4). We will also use the methods in this protocol to evaluate BART control options. Since we are in the process of evaluating control options, no specific emission rates or exhaust characteristics based on BART control options are provided in this protocol.

The main components of the CALPUFF modeling system are CALMET, CALPUFF, and CALPOST. CALMET is the meteorological model that generates hourly three-dimensional meteorological fields such as wind and temperature. CALPUFF simulates the non-steady state transport, dispersion, and chemical transformation of air pollutants emitted from a source in "puffs". CALPUFF calculates hourly concentrations of visibility affecting pollutants at each specified receptor in a modeling domain. CALPOST is the post-processor for CALPUFF, and CALPOST computes visibility impacts from a source based on the visibility affecting pollutant concentrations that were produced by CALPUFF.

2.1 MODEL VERSIONS

Earth Tech, Inc. is the primary developer of the CALPUFF modeling system and all related programs. The versions of the CALPUFF modeling system programs that will be used to model La Cygne Unit 1 and Unit 2 are listed in Table 2-1. Table 2-1 also compares the program versions that will be used to model La Cygne Unit 1 and Unit 2 with the program versions recommended by CENRAP. Note that some of the program versions are not the same as the program versions recommended by CENRAP. The program versions are different due to the fact that several of the program versions recommended by CENRAP are incompatible with each other as published. Specifically, the MM5 data extraction program (CALMM5) Version 2.4 is not compatible with CALMET Version 5.53a. CALMM5 Version 2.4 is compatible with a newer version of CALMET, Version 5.551. Note that meteorological data that is generated with CALMET Version 5.551 is not compatible with CALPUFF Version 5.711a. CALMET Version 5.551 is compatible with CALPUFF Version 5.727. In short, alternate program versions are required in order to accommodate the MM5 data extraction program version, so KCP&L will use alternate versions.

TABLE 2-1. CALPUFF MODELING SYSTEM VERSIONS

	CENRAP Suggested		KCP&L Analyses		Reason for Difference
Program	Version	Level	Version	Level	
TERREL	3.311	030709	3.311	030709	
CTGCOMP	2.42	030709	2.22	030528	Version recommended is not available
CTGPROC	2.42	030709	2.42	030709	
MAKEGEO	2.22	030709	2.22	030709	
CALMM5	2.4	050413	2.4	050413	Modified code used by Alpine Geophysics
CALMET	5.53a	040716	6.211	060414	Needed to process multiple CALMM5 files
CALPUFF	5.711a	040716	6.112	060412	Needed to process CALMET output
POSTUTIL	5.51	030709	6.131	060410	Needed to process CALPUFF output
CALPOST	3.311	030709	3.311	030709	

2.2 Modeling Domain

The modeling domain for the La Cygne Generating Station is the same domain that has been calculated for other BART-eligible electric generating units in Kansas. The domain extends at least 50 km in all directions beyond the La Cygne Generating Station and the five Class I areas of interest. The map projection for the modeling domain is Lambert Conformal Conic (LCC) and the coordinate system is World Geodetic System 1984 (WGS84), which is an LCC projection. The meteorological grid spacing is 2.5 km.

The southwest corner of the modeling domain is Latitude 33.92°N, Longitude 99.35°W which will be assigned as the 0, 0 reference point for the domain. The northeast corner of the modeling domain is approximately Latitude 39.77°N, Longitude 89.29°W. At a grid spacing of 2.5 km, the number of X grid cells will be 346 and the number of Y grid cells will be 261.

Figure 2-1 provides a plot of the modeling domain with respect to the sources and Class I areas.




FIGURE 2-1. PROPOSED MODELING DOMAIN

KCP&L will conduct a three-year CALMET analysis that incorporates both mesoscale model and observation meteorological data. The CALMET analysis will generate three years of data that will be input to CALPUFF. The CALMET model requires the input of geophysical data, meteorological data, and model parameter settings. The CALMET modeling procedures that will be used will generally follow the recommendations in CENRAP's protocol. However, some of CENRAP's recommendations only apply to CALMET analyses that incorporate mesoscale model meteorological data (and no observation data). Since the CALMET analysis for KCP&L's modeling will be a hybrid analysis (mesoscale model data plus observation data), it is expected that some parameters will be different.

3.1 GEOPHYSICAL DATA

CALMET requires geophysical data to characterize the terrain and land use parameters that potentially affect dispersion. Terrain features affect flows and create turbulence in the atmosphere and are potentially subjected to higher concentrations of elevated puffs. Different land uses exhibit variable characteristics such as surface roughness, albedo, Bowen ratio, and leaf-area index that also effect turbulence and dispersion.

3.1.1 TERRAIN DATA

Terrain data from the United States Geological Survey (USGS) in 1-degree (1:250,000 scale or approximately 90 meter resolution) digital format will be used. A list of the USGS terrain files is provided in Appendix A. A plot of the land elevation for the modeling domain based on the referenced files is provided in Figure 3-1.




FIGURE 3-1. PLOT OF LAND ELEVATION USING USGS TERRAIN DATA

The USGS terrain data will be input into the TERREL program to generate grid-cell elevation averages across the modeling domain.

3.1.2 LAND USE DATA

USGS Composite Theme Grid (CTG) format Land Use and Land Cover (LULC) data files at 1:250,000 resolution will be used, where available. Where 1:250,000 land use data is not available, USGS data at 1:100,000 resolution will be used. A list of the USGS land use files is provided in Appendix A. A plot of the land use for the modeling domain based on the referenced files is provided in Figure 3-2.




FIGURE 3-2. PLOT OF LAND USE USING USGS LULC DATA

The LULC data will be input into the CTGPROC program to generate land use for each grid cell across the modeling domain. The USGS CTG format LULC data files must be compressed prior to use in the CTGPROC utility processor; therefore the files will be compressed using the program CTGCOMP.

3.1.3 COMPILING TERRAIN AND LAND USE DATA

The terrain data files output by the TERELL program and the LULC files output by CTGPROC program will be input to the program MAKEGEO to create a geophysical data file that will be input to CALMET.

3.2 METEOROLOGICAL DATA

CALMET will be used to assimilate data for 2001, 2002, and 2003 using mesoscale model output and National Weather Service (NWS) surface station observations and precipitation station observations to develop the meteorological field.

3.2.1 MESOSCALE MODEL METEOROLOGICAL DATA

Hourly mesoscale data will be used to supplement the hourly surface, upper air, and precipitation observation data. The mesoscale data will be used to define the initial guess

field for the CALMET simulations. The following 5th generation mesoscale model (MM5) meteorological data sets will be used:

- 2001 MM5 data at 12 km resolution processed for EPA by Alpine Geophysics
- 2002 MM5 data at 36 km resolution processed by Iowa DNR
- 2003 MM5 data at 36 km resolution processed by the Midwest RPO

The MM5 data for the CENRAP region was extracted from the above MM5 data sets by Alpine Geophysics using the CALMM5 program. Trinity will use this extracted MM5 data.

3.2.2 SURFACE METEOROLOGICAL DATA

Parameters affecting turbulent dispersion that are observed hourly at surface stations include wind speed and direction, temperature, cloud cover and ceiling, relative humidity, and precipitation type. The surface stations from which data will be extracted are listed in Appendix B. The locations of the surface stations with respect to the modeling domain are shown in Figure 3-3. These stations were selected from the available data inventory to optimize spatial coverage and representation of the domain. Data from the stations will be processed for use in CALMET using Version 5.55, Level: 050311 of EPA's SMERGE program.




FIGURE 3-3. PLOT OF SURFACE STATIONS

3.2.3 PRECIPITATION METEOROLOGICAL DATA

The effects of chemical transformations and deposition processes on ambient pollutant concentrations will be considered in this analysis. Therefore, it is necessary to include observations of precipitation in the CALMET analysis. The precipitation stations from which data will be extracted are listed in Appendix B. The locations of the precipitation stations with respect to the modeling domain are shown in Figure 3-4. These stations were selected from the available data inventory to optimize spatial coverage and representation of the domain. Data from the stations will be processed for use in CALMET using Version 5.31, Level: 030528 of EPA's PMERGE program.




FIGURE 3-4. PLOT OF PRECIPITATION METOROLOGICAL STATIONS

3.3 SUMMARY OF CALMET CONTROL PARAMETERS

Table 3-1 provides a listing of the CALMET parameters will be used in the modeling analysis. In addition to the parameters that will be used for the modeling, the table also lists CENRAP's recommended parameters for comparison. In cases where a parameter to be used is different than what CENRAP recommended, a short explanation as to the difference is proved. Note that most of the differences from CENRAP's recommended parameters are due to the inclusion of observation data into the modeling analysis, since CENRAP's parameters are based on a no-observation analysis.

TABLE 3-1. SUMMARY OF CALMET INPUTS

		Value		1
		Included in		
CALMET		CENRAP	Value VCD %I	
CALMET	Description		Value KCP&L	NT
Variable	Description	Protocol	Will Use	Notes
NUSTA	Number of upper air data	0	0	Will not use
	sites	0	_	observations
NOWSTA	sites		0	
IBYR	Starting year	2001	Appropriate met year	Years 2001, 2002, 2003
IBMO	Starting month	1	Appropriate	Due to file size, analysis
IDWO	Starting month	1	month	will be completed by month
IBHR	Starting hour	1	1	
IBTZ	Base time zone	6	6	
IRLG	Length of run	6	Varies with	Due to file size, analysis
III.	Bengui of run	O O	month	will be completed by
IRTYPE	Run type (1 for	1	1	monun
IKITIL	CALPUFF)	1	1	
LCALGRD	Compute CALFRID data	F	F	
	fields ($T = run CALGRID$)			
ITEST	Stop run after SETUP to	2	2	
	do input QA $(2 = run)$	_	_	
PMAP	Map projection	LCC	LCC	
RLAT0	Latitude (decimal degrees)	40N	33.9195N	Appropriate for domain
ICE/110	of projection origin	1011	33.717311	rippropriate for domain
RLON0	Longitude (decimal	97W	99.3480W	Appropriate for domain
	degrees) of projection	, , , ,		
	origin			
XLAT1	Latitude of 1 st standard	33N	33N	Appropriate for domain
112/11/1	parallel	3311	3311	rippropriate for domain
XLAT2	Latitude of 2 nd standard	45N	40N	Appropriate for domain
71L/112	parallel	1311	1011	rippropriate for domain
DATUM	Datum region for output	WGS-G	WGS-G	Selected datum to match
DITT CIVI	coordinates	,, G5 G	11 05 0	datum of land use data
NX	Number of X grid cells in	300	346	Appropriate for domain
11/21	meteorological grid	300	340	rippropriate for domain
NY	Number of Y grid cells in	192	261	Appropriate for domain
111	meteorological grid	1)2	201	Appropriate for domain
DGRIDKM	Grid spacing (km)	6.0	2.5	Refined grid spacing
XORIGKM	Ref. coordinate of SW	-1008	0	Appropriate for domain
11010101111	corner of grid cell	1000		Tippropriate for domain
YORIGKM	Ref. coordinate of SW	0.0	0	Appropriate for domain
101001011	corner of grid cell	0.0		ppropriate for domain
NZ	Number of vertical layers	10	10	
ZFACE	Vertical cell face heights	0, 20, 40, 80,	0, 20, 40, 80,	
LIACE	(NZ + 1 values)	160, 320, 640,	160, 320, 640,	
	(112 T 1 values)	1200, 2000,	1200, 2000,	
		3000, 4000	3000, 4000	
		5000, 4000	3000, 4000	

		X7 1		1
		Value		
GAY MET		Included in	*** *** ******	
CALMET		CENRAP	Value KCP&L	
Variable	Description	Protocol	Will Use	Notes
LSAVE	Save met. data fields in an unformatted file?	Т	T	
IFORMO	Type of unformatted	1	1	
	output file (1 for			
	CALPUFF)			
LPRINT	Print met. fields	F	F	
IPRINF	Print intervals	1	1	
IUVOUT(NZ)	Specify layers of u,v wind	NZ*0	NZ*0	
l	components to print			
IWOUT(NZ)	Specify layers of w wind	NZ*0	NZ*0	
	component to print			
ITOUT(NZ)	Specify layers of 3D	NZ*0	NZ*0	
	temperature field to print			
LDB	Print met data and	F	F	
	variables	•	•	
NN1	First time step for debug	1	1	
1111	data to be printed	1	1	
NN2	Last time step for debug	1	2	Will generate debug data
11112	data to be printed	1	2	for a total of 2 time steps
IOUTD	Control variable for	0	0	for a total of 2 time steps
10010	writing test/debug wind	U	U	
	fields			
NZPRN2	Number of levels starting	0	1	Default
NZFKNZ	at surface to print	U	1	Default
IPRO	Print interpolated wind	0	0	
IPRO		U	U	
IPR1	components Print terrain adjusted	0	0	
IPKI	surface wind components	U	U	
IPR2	*	0	0	
IPK2	Print initial divergence fields	U	U	
IPR3		0	0	
IPK3	Print final wind speed and	U	U	
IDD 4	direction		0	
IPR4	Print final divergence fields	0	0	
IDD 5			0	
IPR5	Print winds after kinematic	0	0	
IDD (effects		0	
IPR6	Print winds after Froude	0	0	
	number adjustment			
IPR7	Print winds after slope	0	0	
IDDO	flows are added			
IPR8	Print final wind field	0	0	
NO.07.7	components			******
NOOBS	No observation mode (2 =	2	1	Will use surface
	No surface, overwater, or			observations only
	upper air observations; use			
	MM5 for surface,			
	overwater, and upper air			
NICOTA	data)	0	4.5	NIl C
NSSTA	Number of meteorological	0	45	Number of stations
	stations in SURF.DAT file			

		Value		
		Included in		
CALMET		CENRAP	Value KCP&L	
Variable	Description	Protocol	Will Use	Notes
NPSTA	NPSTA Number of precipitation stations in PRECIP.DAT file		206	Number of stations
ICLOUD	Gridded cloud fields (0 = no, 3 = Gridded cloud cover from prognostic relative humidity)	3	0	
IFORMS	Format of surface data (2 = formatted)	2	2	
IFORMP	Format of precipitation data (2 = formatted)	2	2	
IFORMC	Format of cloud data (2 = formatted)	2	1	N/A - No cloud data used in model
IWFCOD	Generate winds by diagnostic wind module? (1 = yes)	1	1	
IFRADJ	Adjust winds using Froude number effects? (1 = yes)	1	1	
IKINE	Adjust winds using kinematic effects? (0 = no)	0	1	Will compute kinematic effects in this analysis
IOBR	Use O'Brien procedure for vertical winds? (0 = no)	0	0	
ISLOPE	Compute slope flows? (1 = yes)	1	1	
IEXTRP	Extrapolate surface winds to upper layers (-1 = no extrapolation and ignore layer 1 of upper air station data)	-1	-4	-4 = Since observations are included in model, will use similarity theory and ignore layer 1 of upper air station data (FLAG default)
ICALM	Extrapolate surface winds even if calm? (0 = no)	0	0	
BIAS	Layer dependent biases weighting aloft measurements	0, 0, 0, 0, 0, 0, 0, 0, 0, 0, 0, 0, 0	0, 0, 0, 0, 0, 0, 0, 0, 0, 0	
RMIN2	Minimum vertical extrapolation distance Distance (km) around an upper air site where vertical extrapolation is excluded (set to -1 if IEXTRP = ± 4)	-1	-1	
IPROG	Using prognostic or MM- FDDA data? (14 = Use winds from MM5.DAT as initial guess wind field)	14	14	
ISTEPPG	Timestep (hours) of the MM5 data	1	1	

		Value		
		Included in		
CALMET		CENRAP	Value KCP&L	
Variable	Description	Protocol	Will Use	Notes
LVARY	Use varying radius of	T	F	Use FLAG default
	influence to develop			
	surface winds?			
RMAX1	Maximum radius of	30	100	
	influence over land in			
D) (1 7/2	surface layer (km)	20	7 00	
RMAX2	Maximum radius of	30	500	
	influence over land aloft			
DMAN2	(km)	50	100	
RMAX3	Maximum radius of influence over water (km)	50	100	
RMIN	Minimum radius of	0.1	0.1	
KIVIIIN	influence used anywhere	0.1	0.1	
	(km)			
TERRAD	Radius of influence of	12	12	
ILKKAD	terrain features (km)	12	12	
R1	Weighting of first guess	1	80	
	surface field (km)	_		
R2	Weighting of first guess	1	200	
	aloft field (km)			
RPROG	MM5 windfield weighting	0	0	
	parameter (km)			
DIVLIM	Maximum acceptable	5.E-6	5.E-6	
	divergence			
NITER	Max number of passes in	50	50	
	divergence minimization			
NSMTH	Number of passes through	2, 4, 4, 4, 4, 4,	2, 4, 4, 4, 4, 4,	
	smoothing filter in each	4	4, 4, 4, 4	
	layer of CALMET (NZ			
	values)			
NITR2	Max number of stations	5, 5, 5, 5, 5, 5,	5, 5, 5, 5, 5, 5,	
	used in each layer for the	5, 5, 5, 5	5, 5, 5, 5	
	interpolation of data to a			
CRITFM	grid point (NZ values) Critical Froude number	1.0	1.0	
ALPHA	Kinematic effects	0.1	0.1	
ALFHA	parameter	0.1	0.1	
FEXTR2	Scaling factor for	NZ*0.0	NZ*0.0	
11/3111/2	extrapolating surface	112 0.0	112 0.0	
	winds aloft			
NBAR	Number of terrain barriers	0	0	
IDIOTP1	Compute temperature	0	0	
	from observations (0 =		-	
	true)			
ISURFT	Surface station to use for	4	4	
	surface temperature			
	(between 1 and NSSTA)			
IDIOPT2	Domain-averaged wind	0	0	
	component switch			

	T	Value		
		Value Included in		
CALMET		CENRAP	Value KCP&L	
Variable	Description	Protocol	Will Use	Notes
IUPT	Station for lapse rates	2	2	Notes
	(between 1 and NUSTA)			
ZUPT	Depth through which lapse rate is calculated	200	200	
IDIOPT3	Domain averaged wind component switch	0	0	
IUPWND	Upper air station for domain winds	-1	-1	
ZUPWND	Bottom and top of layer through which the domain scale winds are computed	1., 1000.	1., 1000.	
IDIOPT4	Observed surface wind component switch	0	0	
IDIOPT5	Observed aloft wind component switch	0	0	
LLBREZE	Use lake breeze module?	F	F	
NBOX	Number of lake breeze	0	0	
	regions			
NLB	Number of stations in the region	0	0	
METBXID(NLB)	Station IDs in the region	0	0	
CONSTB	Neutral stability mixing height coefficient	1.41	1.41	
CONSTE	Convective stability mixing height coefficient	0.15	0.15	
CONSTN	Stable stability mixing height coefficient	2400	2400	
CONSTW	Overwater mixing height coefficient	0.16	0.16	
FCORIOL	Absolute value of Coriolis parameter	1.E-4	1.E-4	
IAVEZI	Conduct spatial averaging? (1 = yes)	1	1	
MNMDAV	Max search radius in averaging process (number of grid cells)	10	10	
HAFANG	Half-angle of upwind looking cone for averaging (degrees)	30	30	
ILEVZI	Layers of wind use in upwind averaging (between 1 and NZ)	1	1	
DPTMIN	Minimum potential temperature lapse rate in the stable layer above the current convective mixing height	0.001	0.001	

		Value		
		Included in		
CALMET		CENRAP	Value KCP&L	
Variable	Description	Protocol	Will Use	Notes
DZZI	Depth of layer above	200	200	
	current convective mixing	_00		
	height through which lapse			
	rate is computed (m)			
ZIMIN	Minimum overland mixing	50	50	
	height (m)			
ZIMAX	Maximum overland	3000	3000	
	mixing height (m)			
ZIMINW	Minimum overwater	50	50	
	mixing height (m)			
ZIMAXW	Maximum overwater	3000	3000	
	missing height (m)			
ITPROG	3D temperature from	2	1	Will use surface
	observations or from			observations
	MM5?			
IRAD	Type of interpolation (1 =	1	1	
	1/r)			
TRADKM	Temperature interpolation	36	36	
	radius of influence (km)			
NUMTS	Max number of stations	5	5	
	for temperature			
	interpolations			
IAVET	Spatially average	1	1	
	temperature? $(1 = yes)$			
TGDEFB	Temperature gradient	0098	-0.0098	
	below the mixing height			
	over water (K/m)			
TGDEFA	Temperature gradient	0045	-0.0045	
	above the mixing height			
	over water (K/m)			
JWAT1	Beginning land use	55	55	
	categories over water			
JWAT2	Ending land use categories	55	55	
	for water			
NET A CE				
NFLAGP	Precipitation interpolation	2	2	
CICIAAD	flag $(2 = 1/r^2)$	<i>F</i> 0	70	
SIGMAP	Radius of influence for	50	50	
	precipitation interpolation			
CLITD	(km)	0.01	0.01	
CUTP	Minimum precipitation rate cut off (mm/hr)	0.01	0.01	
	rate cut off (mm/nr)			1

KCP&L will conduct a three-year CALPUFF analysis. The CALPUFF model requires the input of meteorological data output by CALMET, source emissions data, receptor data, ozone and ammonia data, and model parameter settings.

4.1 Source Emissions Data

The BART rule indicates that if the PTE is greater than 250 tpy for any visibility-impairing pollutant, a source is required to include emissions of all visibility impairing pollutants in the BART analysis. La Cygne Unit 1 and Unit 2 emit three primary visibility-impairing pollutants: SO₂, PM₁₀, and NO_X. Since the PTE for at least one of these pollutants is above 250 tpy, KCP&L will include emissions of all three pollutants in the BART modeling analysis.

4.1.1 SO₂, NO_x, AND PM₁₀ EMISSIONS

The BART rule indicates that KCP&L should model the highest actual 24-hour emission rate for each visibility impairing pollutant that occurred during a baseline period. Thus, the SO_2 , NO_x , and PM_{10} emissions that will be modeled to determine the current visibility impacts attributable to La Cygne Unit 1 and Unit 2 are the maximum of the 2002-2004 24-hour highest actual emissions rates. The SO_2 and NO_x emission rates will be based on CEMS data. The PM_{10} emission rates will be based on actual fuel data from 2002-2004 and AP-42 emission factors. The PM_{10} emission rates will include both the filterable and condensable fractions. Detailed calculations for the PM_{10} emission rates can be found in Appendix C. The SO_2 , NO_x , and PM_{10} emissions are summarized in Table 4-1.

SO₂ NO_X PM₁₀
(lb/hr) (lb/hr) (lb/hr)

La Cygne - Unit 1 6,151.15 11,589.52 53.79

La Cygne - Unit 2 8,316.15 3,543.47 94.92

TABLE 4-1. SO₂, NO_X AND PM₁₀ EMISSIONS

4.1.2 SPECIATED PM₁₀ EMISSIONS

The PM₁₀ emissions will be speciated to include the following:

- Coarse particulate matter (PM_C)
- Fine particulate matter (PM_f)
- Sulfates (SO₄)
- Nitrates (NO₃)
- Secondary organic aerosols (SOA)
- Elemental carbon (EC)

The PM₁₀ emissions will be speciated according to the default speciation profiles prepared by the Federal Land Managers (FLM) for a Cyclone Furnace with Flue Gas Desulfurization (FGD) and ESP

(La Cygne Unit 1) and a dry bottom PC boiler with ESP (La Cygne Unit 2). It should be noted that Unit 1 is a cyclone furnace with wet FGD only; however, there is not an FLM PM_{10} speciation for this type of cyclone boiler. Therefore, the FLM PM_{10} speciation for a Cyclone Furnace with FGD and ESP was used. Since the wet FGD controls PM, this speciation is appropriate for Unit 1. Table 4-2 provides a summary of the speciated emissions.

TABLE 4-2. HOURLY PM₁₀ SPECIATED EMISSIONS

	Total PM10	SO4	PM_c	$PM_{\rm f}$	SOA	EC
	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)
La Cygne - Unit 1	53.79	34.37	4.92	5.68	8.59	0.22
La Cygne - Unit 2	94.92	28.12	33.20	25.58	7.03	0.98

4.2 GEP STACK HEIGHT

Section 6.2.2 of the Guideline on Air Quality Models¹ states the following:

"The use of stack height credit in excess of Good Engineering Practice (GEP) stack height or credit resulting from any other dispersion technique is prohibited in the development of emission limitations by 40 CFR 51.118 and 40 CFR 51.164."

Since this modeling is being used to determine if emissions limitations are needed, stack heights in excess of GEP stack heights should not be used in the modeling. KCP&L has calculated the GEP stack heights of La Cygne Unit 1 and Unit 2 and determined that the actual heights are in excess of GEP stack height.

The EPA provides guidance for determining whether building downwash will occur in *Guideline for Determination of Good Engineering Practice Stack Height.*² The minimum stack height not subject to the effects of downwash (called the Good Engineering Practice or GEP stack height) is defined by the following formula:

GEP = H + 1.5L

Where: GEP = the minimum GEP stack height H = the height of the structure

L = the lesser dimension of the structure (height or projected

width)

Stacks located more than 5L from any building are not subject to the effects of building downwash.

¹ 40 CFR 51, Appendix W

²EPA, Office of Air Quality Planning and Standards. *Guideline for Determination of Good Engineering Practice Stack Height (Technical Support Document for the Stack Height Regulations) (Revised).* Research Triangle Park, North Carolina. EPA 450/4-80-023R. June, 1985.

Calculations for determining the direction-specific downwash parameters and GEP stack height were performed using *BREEZE*TM WAKE/BPIP software, which uses EPA's Building Profile Input Program (BPIP) downwash algorithm. Figure 4.1 shows the stacks and buildings that were included in the BPIP analysis. Since the GEP stack heights are less than the actual stack heights, the stacks will be modeled at GEP stack heights rather than the actual stack heights. A summary of the stack parameters, including GEP and actual stack heights, can be found in Table 4-3. These parameters are only specific to the existing operations; as KCP&L evaluates BART control options, the parameters may be modified for each control option.




FIGURE 4-1. LA CYGNE STACK AND BUILDING LOCATIONS

TABLE 4-3. SUMMARY OF STACK PARAMETERS

	La Cygne 1	La Cygne 2
Latitude (degrees)	38.3486	38.3476
Longitude (degrees)	-94.6456	-94.6456
Actual Stack height (ft)	700	700
GEP Stack height (ft)	591.2	597.8
Stack Diameter (ft)	23	24
Exhaust Velocity (ft/s)	92.7	100.8
Exhaust Temperature (F)	127	281

4.3 CLASS I AREA RECEPTORS

The National Park Service (NPS) has electronic files for each Class I area available on their website containing the locations and elevations of discrete Class I area receptors. The receptor files for all Class I areas will be downloaded from the NPS website, converted into the LCC WGS84 projection, and incorporated into the CALPUFF model. The receptor locations for the Class I areas are shown in Figures 4-2 through 4-6.

FIGURE 4-2. HERCULES-GLADES WILDERNESS RECEPTOR LOCATIONS




FIGURE 4-3. WICHITA MOUNTAINS RECEPTOR LOCATIONS




FIGURE 4-4. UPPER BUFFALO RECEPTOR LOCATIONS




FIGURE 4-5. CANEY CREEK RECEPTOR LOCATIONS





FIGURE 4-6. MINGO RECEPTOR LOCATIONS



4.4 BACKGROUND OZONE

Background ozone concentrations are required in order to model the photochemical conversion of SO_2 and NO_x to sulfates (SO_4) and nitrates (NO_3). CALPUFF can use either a single background value representative of an area or hourly ozone data from one or more ozone monitoring stations. CENRAP recommends either developing background ozone estimates from ambient monitors located within the particular domain being modeled or developing background ammonia estimates from CENRAP's most recent CMAQ or CAMx simulation for the 2002 base year. KCP&L is proposing to incorporate hourly ozone data from three rural ozone monitors across the state of Kansas. The three monitors are listed in Table 4-4.

TABLE 4-4. SUMMARY OF OZONE MONITORS

Monitor ID	County	Latitude	Longitude
201910002 (Peck)	Sumner	37.477	97.366
201950001 (Cedar Bluff)	Trego	38.770	99.764
20107002 (Mine Creek)	Linn	38.135	94.732

Andy Hawkins of KDHE has made available processed ozone data files for 2001 through 2003 containing data from the above referenced stations. KCP&L is proposing to incorporate these files into the CALPUFF model.

4.5 BACKGROUND AMMONIA

Background ammonia concentrations are required to model the formation of ammonium sulfates and ammonium nitrates. CENRAP recommends developing background ammonia estimates from CENRAP's most recent CMAQ or CAMx simulation for the 2002 base year. Since CMAQ/CAMx modeled and observed monthly averaged ammonia concentrations exhibit wide spatial variability, CENRAP recommends obtaining separate monthly-averaged ammonia concentrations from CMAQ or CAMx for the CENRAP north, central and south modeling domains, respectively. These would then be used as input to CALPUFF. Since the data from CENRAP's CMAQ and CAMx simulations are not readily available, KCP&L is proposing to use a conservative monthly background concentration of 3 ppb. This background concentration is the value included in CENRAP's protocol as a default background value for the CENRAP region.

4.6 SUMMARY OF CALPUFF CONTROL PARAMETERS

Table 4-5 provides a listing of the CALPUFF parameters that KCP&L proposes to use in the modeling analysis. In addition to the parameters that will be used, the table also lists CENRAP's recommended parameters for comparison. In cases where a parameter to be used is different than what CENRAP recommended, a short explanation as to the difference is proved.

TABLE 4-5. SUMMARY OF CALPUFF INPUTS

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
METRUN	All model periods	0	0	
	in met files will be			
	run			
IBYR	Starting year	2001	Appropriate met year	Years 2001, 2002, 2003
IBMO	Starting month	1	1	
IBDY	Starting day	1	1	
IBHR	Starting hour	1	1	
XBTZ	Base time zone (6	6	6	
	= CST)			
IRLG	Length of run	8760	8760	
NSPEC	Number of	10	9	
	MESOPUFF II			
	chemical species			
NSE	Number of	8	7	Appears to be an
	chemical species			error in CENRAP's
	to be emitted			count of the emitted
				species (only 7 listed
				in Table B-4 of
				protocol)

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
ITEST	Program is	2	2	
	executed after			
	SETUP phase			
MRESTART	Do not read or	0	0	
	write a restart file			
NRESPD	during run File written only at	0	0	
NKESI D	last period	U		
METFM	CALMET binary	1	1	
	file			
	(CALMET.MET)			
AVET	Averaging time in	60	60	
	minutes			
PGTIME	PG Averaging	60	60	
3.60.43300	time in minutes			
MGAUSS	Gaussian	1	1	
	distribution used in near field			
MCTADJ	Partial plume path	3	3	
WICTADJ	terrain adjustment	3		
MCTSG	Sub-grid-scale	0	0	
	complex terrain			
	not modeled			
MSLUG	Near-field puffs	0	0	
	not modeled as			
	elongated			
MTRANS	Transitional plume	1	1	
MTIP	rise modeled	1	1	
WITT	Stack tip downwash used	1		
MSHEAR	(0, 1) Vertical	0	0	
	wind shear (not			
	modeled,			
	modeled)			
MSPLIT	Puffs are not split	0	1	Included puff
				splitting due to
				significant distance between sources and
				Class I areas
MCHEM	MESOPUFF II	1	1	Class I alcas
WEILEN	chemical	1		
	parameterization			
	scheme			
MAQCHEM	Aqueous phase	0	0	
	transformation not			
MANAGE	modeled	1	1	
MWET	Wet removal modeled	1	1	
MDRY	Dry deposition	1	1	
MIDKI	modeled	1	1	
MDISP	PG dispersion	3	3	
	coefficients	-		

CALPUFF				ncluded in		KCP&L		
Variable		ription		AP Protocol		l Use	N	lotes
MTURBVW	Use both	$\sigma_{\rm v}$ and	3		3			
	$\sigma_{\rm w}$ from							
		E.DAT to						
	_	σ_{y} and σ_{z}						
MDICD2	(n/a)	•	3		2			
MDISP2	PG dispe		3		3			
MROUGH	PG σ_{y} an		0		0			
WIKOCOII	adjusted		O					
	roughnes							
MPARTL	No partia		1		1			
	penetrati							
		inversion						
MTINV	Strength		0		0			
	temperat							
	inversion computed							
	default g							
MPDF	PDF not		0		0			
	dispersio	n under						
	convectiv	ve						
	condition							
MSGTIBL	Sub-grid		0		0			
	module r							
MBCON	Boundar		0		0			
WIDCON	concentra		U		U			
	condition							
	modeled							
MFOG	Do not co		0		0			
	for FOG	model						
MDEG	output	1			1			
MREG	must con	options	1		1			
	USEPA 1							
	Range Ti	_						
	(LRT) gu							
CSPEC		CE	NRAP			KC	P&L	
	Output			_	Output			_
	Group	M. 111	TT *44 *	Dry	Group	M. 11 1	TC *44 *	Dry
	Species	Modeled 1	Emitted 1	Deposition	Species	Modeled 1	Emitted 1	Deposition
	SO ₂	_	-	2	SO ₂		_	_
	SO4 NOX	1	1	1	NOX	1	1	1
	HNO3	1	0	1	HNO3	1	0	1
	NO3	1	0	2	NO3	1	0	2
	PMC	1	1	2	PMC	1	1	2
	PMF	1	1	2	PMF	1	1	2
	EC	1	1	2	EC	1	1	2
	SOA	1	1	2	SOA	1	1	2
PMAP	Map proj	jection	UTM	-	LCC			<u></u>

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
NX	Number of X grid cells in meteorological grid	66	346	Appropriate for domain and grid spacing
NY	Number of Y grid cells in meteorological grid	66	261	Appropriate for domain and grid spacing
NZ	Number of vertical layers in meteorological grid	10	10	
DGRIDKM	Grid spacing (km)	6	2.5	Refined grid size
ZFACE	Cell face heights in meteorological grid (m)	0, 20, 40, 80, 160, 320, 640, 1200, 2000, 3000, 4000	0, 20, 40, 80, 160, 320, 640, 1200, 2000, 3000, 4000	
XORIGKM	Reference X coordinate for SW corner of grid cell of meteorological grid (km)	5	0	Appropriate for domain
YORIGKM	Reference Y coordinate for SW corner of grid cell of meteorological grid (km)	3327	0	Appropriate for domain
IUTMZN	UTM zone of coordinates (NAD83)	12	14	Appropriate for domain
IBCOMP	X index of lower left corner of the computational grid	1	1	
JBCOMP	Y index of lower left corner of the computational grids	1	1	
IECOMP	X index of upper right corner of the computational grid	66	346	Appropriate for domain
JECOMP	Y index of upper right corner of the computational grid	66	261	Appropriate for domain
LSAMP	Sampling grid is not used	F	F	
IBSAMP	X index of lower left corner of sampling grid	1	1	
JBSAMP	Y index of lower left corner of sampling grid	1	1	
IESAMP	X index of upper right corner of sampling grid	66	346	Appropriate for domain

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
JESAMP	Y index of upper	66	261	Appropriate for
	right corner of			domain
MEGLIDA	sampling grid	4	1	
MESHDN	Nesting factor of	1	1	
ICON	sampling grid Output file	1	1	
ICON	CONC.DAT	1	1	
	containing			
	concentrations is			
	created			
IDRY	Output file	1	1	
	DFLX.DAT			
	containing dry fluxes is created			
IWET	Output file	1	1	
IWEI	WFLX.DAT	1	1	
	containing wet			
	fluxes is created			
IVIS	Output file	1	1	
	containing relative			
	humidity data is			
T COMPRE	created	T.	T	
LCOMPRS	Perform data	T	T	
	compression in output file			
IMFLX	Do not calculate	0	0	
11/11/21/1	mass fluzes across			
	specific			
	boundaries			
IMBAL	Mass balances for	0	0	
	each species not			
ICPRT	reported hourly Print concentration	1	1	
ICPKI	fields to output list		1	
	file			
IDPRT	Do not print dry	0	0	
	flux fields to			
	output list file			
IWPRT	Do not print wet	0	0	
	flux fields to			
ICFRQ	output list file Concentration	1	1	
1CI KŲ	fields are printed	1	1	
	to output list file			
	every hour			
IDFRQ	Dry flux fields are	1	1	
	printed to output			
	list file every 1			
TWED C	hour	1	1	
IWFRQ	Wet flux fields are printed to output	1	1	
	list file every 1			
	hour			
		I.	ı	1

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
IPTRU	Units for line	3	3	
	printer output are			
	in g/m ³ for			
	concentration and			
	g/m ² /s for			
	deposition			
IMESG	Messages tracking	2	2	
	the progress of run			
	written to screen			
LDEBUG	Logical value for	F	F	
	debug output			
IPFDEB	First puff to track	1	1	
NPFDEB	Number of puffs	1	1	
	to track			
NN1	Meteorological	1	1	
	period to start			
	output			
NN2	Meteorological	10	10	
	period to end			
	output			
NHILL	Number of terrain	0	0	
	features			
NCTREC	Number of special	0	0	
	complex terrain			
	receptors			
MHILL	Input terrain and	2	2	
	receptor data for			
	CTSG hills input in CTDM format			
XHILL2M	Conversion factor	1	1	
XHILL2M	for changing	1	1	
	horizontal			
	dimensions to			
	meters			
ZHILL2M	Conversion factor	1	1	
21111112111	for changing	•		
	vertical			
	dimensions to			
	meters			
XCTDMKM	X origin of CTDM	0	0	
	system relative to			
	CALPUFF			
	coordinate system			
	(km)			
YCTDMKM	Y origin of CTDM	0	0	
	system relative to			
	CALPUFF			
	coordinate system			
	(km)			
SO2	Diffusivity	0.1509	0.1509	
	Alpha star	1000	1000	
	Reactivity	8	8	

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
	Mesophyll	0	0	
	resistance			
	Henry's Law	0.04	0.04	
	coefficient			
NO_X	Diffusivity	0.1656	0.1656	
	Alpha star	1	1	
	Reactivity	8	8	
	Mesophyll	5	5	
	resistance			
	Henry's Law	3.5	3.5	
	coefficient			
HNO3	Diffusivity	0.1628	0.1628	
	Alpha star	1	1	
	Reactivity	18	18	
	Mesophyll	0	0	
	resistance			
	Henry's Law	8.e-8	8.e-8	
~~.	coefficient	0.40		
SO4-2	Geomatric mass	0.48	0.48	
	mean diameter of			
NO2	SO4-2 (μm)	0.40	0.40	
NO3-	Geometric mass	0.48	0.48	
	mean diameter of			
PMC	NO3- (µm) Geometric mass	6	6	
PIVIC	mean diameter of	0	0	
	PMC (µm)			
PMF	Geometric mass	0.48	0.48	
1 1/11	mean diameter of	0.40	0.40	
	PMF (µm)			
EC	Geometric mass	0.48	0.48	
	mean diameter of	0.10	0.10	
	EC (µm)			
SOA	Geometric mass	0.48	0.48	
1	mean diameter of			
1	SOA (µm)			
RCUTR	Reference cuticle	30	30	
	resistance (s/cm)			
RGR	Reference ground	10	10	
	resistance (s/cm)			
REACTR	Reference	8	8	
	pollutant reactivity			
NINT	Number of particle	9	9	
	size intervals for			
	effective particle			
	deposition velocity		1	
IVEG	Vegetation in non-	1	1	
	irrigated areas is			
	active and			
	unstressed		1	

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
SO ₂	Scavenging coefficient for liquid precipitation (s ⁻¹)	3.21E-05	3.E-05	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	0	0	
SO4-2	Scavenging coefficient for liquid precipitation (s ⁻¹)	1.0E-04	1.0E-04	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	3.0E-05	3.0E-05	
HNO3	Scavenging coefficient for liquid precipitation (s ⁻¹)	6.0E-05	6.0E-05	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	0	0	
NO3-	Scavenging coefficient for liquid precipitation (s ⁻¹)	1.0E-04	1.0E-04	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	3.0E-05	3.0E-05	
NH3	Scavenging coefficient for liquid precipitation (s ⁻¹)	8.0E-05	NA	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	0	NA	
PMC	Scavenging coefficient for liquid precipitation (s ⁻¹)	1.0E-4	1.0E-4	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	3.0E-05	3.0E-05	
PMF	Scavenging coefficient for liquid precipitation (s ⁻¹)	1.0E-04	1.0E-04	

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
	Scavenging coefficient for frozen precipitation (s ⁻¹)	3.0E-05	3.0E-05	
EC	Scavenging coefficient for liquid precipitation (s ⁻¹)	1.0E-04	1.0E-04	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	3.0E-05	3.0E-05	
OC	Scavenging coefficient for liquid precipitation (s ⁻¹)	1.0E-04	1.0E-04	
	Scavenging coefficient for frozen precipitation (s ⁻¹)	3.0E-05	3.0E-05	
MOZ	Read ozone background concentrations from ozone.dat file (measured values)	1	1	
ВСКО3	Background ozone concentration (ppb)	12*40	NA	Used ozone data file
BCKNH3	Background ammonia concentration (ppb)	12*3	12*3	
RNITE1	Nighttime NO2 loss rate is %/hour	0.2	0.2	
RNITE2	Nighttime NO _X loss rate is %/hour	2	2	
RNITE3	Nighttime HNO3 loss rate is %/hour	2	2	
MH2O2	Background H2O2 concentrations	1	0	Need to choose 0 in order to use monthly background value
BCKH2O2	Background monthly H2O2 concentrations	1	12*1	
BCKPMF	Fine particulate concentration for SOA option (µg/m³)	1	1	
OFRAC	Organic fraction of fine particulate for SOA option	.2	0.15,0.15,0.2,0.2,0.2, 0.2,0.2,0.2,0.2,0.2, 0.2,0.15	Irrelevant, since MCHEM not equal to 4

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
VCNX	VOC/NO _X ratio	50	50	
	for SOA option			
SYDEP	Horizontal size of a puff in meters beyond which the time dependant dispersion equation of Heffter is used	550	550	
MHFTSZ	Do not use Heffter formulas for sigma z	0	0	
JSUP	Stability class used to determine dispersion rates for puffs above boundary layer	5	5	
CONK1	Vertical dispersion constant for stable conditions	0.01	0.01	
CONK2	Vertical dispersion constant for neutral/stable conditions	0.1	0.1	
TBD	Use ISC transition point for determining the transition point between the Schulman-Scire to Huber-Snyder Building Downwash scheme	0.5	0.5	
IURB1	Lower range of land use categories for which urban dispersion is assumed	10	10	
IURB2	Upper range of land use categories for which urban dispersion is assumed	19	19	
ILANDUIN	Land use category for modeling domain	*	*	
XLAIIN	Leaf area index for modeling domain	*	*	
ZOIN	Roughness length in meters for modeling domain	*	*	

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
ELEVIN	Elevation above	*	*	
	sea level		<u></u>	
XLATIN	North latitude of	-	-	
	station in degrees			
XLONIN	South latitude of	-	-	
ANTENER	station in degrees	10	10	
ANEMHT	Anemometer	10	10	
ICICMAN	height in meters	1	1	
ISIGMAV	Sigma-v is read for lateral	1	1	
	turbulence data			
IMIXCTDM	Predicted mixing	0	0	
	heights are used			
XMXLEN	Maximum length	1	1	
1	of emitted slug in			Į l
1	meteorological			ļ l
***	grid units	10	10	
XSAMLEN	Maximum travel	10	10	
1	distance of slug or			
1	puff in meteorological			Į l
1	grid units during			
1	one sampling unit			Į l
MXNEW	Maximum number	60	60	
	of puffs or slugs			
1	released from one			
1	source during one			Į l
	time step			
MXSAM	Maximum number	60	60	
1	of sampling steps			Į l
1	during one time			
1	step for a puff or slug			
NCOUNT	Number of	2	2	
	iterations used			
1	when computing			
	the transport wind			
	for a sampling step			
	that includes			
	transitional plume			
CVMINT	rise	1	1	
SYMIN	Minimum sigma y in meters for a	1	1	Į l
	new puff or slug			
SZMIN	Minimum sigma z	1	1	
	in meters for a			Į l
	new puff or slug		<u></u>	
SVMIN	Minimum lateral	0.5	0.5	
	turbulence			
	velocities (m/s)			
SWMIN	Minimum vertical	0.20, 0.12, 0.08, 0.06,	0.20, 0.12, 0.08,	
	turbulence	0.03, 0.016	0.06, 0.03, 0.016	
<u> </u>	velocities (m/s)	<u></u>	<u> </u>	

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
WSCALM	Minimum non- calm wind speeds	0.5	0.5	
	(m/s)			
XMAXZI	Maximum mixing	3000	3000	
	height (m)	3000	2000	
XMINZI	Minimum mixing	20	20	
	height (m)			
SL2PF	Maximum σy/puff	10	10	
DI VO	length	0.07.0.07.0.10.0.15	0.07.0.07.0.10	
PLXO	Wind speed	0.07, 0.07, 0.10, 0.15, 0.35, 0.55	0.07, 0.07, 0.10,	
	power-law exponents	0.55, 0.55	0.15, 0.35, 0.55	
WSCAT	Upper bounds of	1.54, 3.09, 5.14, 8.23,	1.54, 3.09, 5.14,	
WSCAI	1 st 5 wind speed	10.80	8.23, 10.80	
	classes		1.20, 10.00	
PGGO	Potential temp	0.020, 0.035	0.020, 0.035	
	gradients PG E &	,	,	
	F (deg/km)			
CDIV	Divergence	0.01	0.01	
	criterion for dw/dz			
	(1/s)			
PPC	Plume path	0.5, 0.5, 0.5, 0.5,	0.5, 0.5, 0.5, 0.5,	
	coefficients (only	0.35, 0.35	0.35, 0.35	
NICDI IT	if MCTADJ = 3)	3	2	
NSPLIT	Number of puffs when split	3	3	
IRESPLIT	Hours when puff	1900	Hour 19	Should be by hour of
IKESI ETI	is eligible to split	1700	Hour 19	day – 1900 is hour 19
ZISPLIT	Previous hours	100	100	
	minimum mixing			
	height, m			
ROLDMAX	Previous max	0.25	0.25	
	mixing			
	height/current			
	height ratio, must			
	be less than this			
	value to allow puff to split			
NSPLITH	Number of puffs	5	5	
I TOT LITT	resulting from a	<i>-</i>		
	split			
SYSPLITH	Minimum sigma-y	1.0	1.0	
	of puff before it			
	may split			
SHSPLITH	Minimum puff	2.0	2.0	
	elongation rate			
	from wind shear			
	before puff may			
	split			

es
ent units
1 1
led

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
NAR2	Number of	-	-	
	buoyant polygon			
	area sources with			
	variable location			
	and emission			
	parameters			
NLN2	Number of	-	0	None modeled
	buoyant line			
	sources with			
	variable location			
	and emission			
	parameters			
NLINES	Number of	-	-	
	buoyant line			
	sources			
ILNU	Units for line	-	-	
	source emission			
	rates in g/s			
NSLN1	Number of source-	-	-	
	species			
	combinations with			
	variable emissions			
	scaling factors			
MXNSEG	Maximum number	-	-	
	of segments used			
	to model each line			
NLRISE	Number of	-	-	
	distance at which			
	transitional rise is			
377	computed			
XL	Average line	-	-	
IIDI	source length (m)			
HBL	Average height of	-	-	
	line source height			
WBL	(m) Average building	_	_	
WDL	width (m)	_	_	
WML	Average line		_	
44 1AIT	source width (m)	_	-	
DXL	Average	_	_	
DAL	separation			
	between buildings			
	(m)			
FPRIMEL	Average buoyancy	_	_	
	parameter (m4/s3)			
NVL1	Number of volume	-	0	None modeled
= . , = .	sources		_	
IVLU	Units for volume	-	-	
. -	source emission			
	rates in			
	grams/second			
		l.	Į.	

CALPUFF		Value Included in	Value KCP&L	
Variable	Description	CENRAP Protocol	Will Use	Notes
NSVL1	Number of source- species combinations with variable emissions scaling factors	-	-	
IGRDVL	Gridded volume source data is not used	-	-	
VEFFHT	Effective height of emissions (m)	-	-	
VSIGYI	Initial sigma-y value	-	-	
VSIGZI	Initial sigma-z value	-	-	
NREC	Number of non- gridded receptors	5630	338	

KCP&L will conduct a three-year CALPOST analysis to determine the change in light extinction caused by La Cygne Unit 1 and Unit 2 when compared to a natural background. The CALPOST model requires the input of concentration data output by CALPUFF.

5.1 LIGHT EXTINCTION ALGORITHM

KCP&L will utilize EPA's currently approved algorithm for reconstructing light extinction (as opposed to the new equation for reconstructing light extinction recommended by the IMPROVE Steering Committee). The light extinction equation is provided below.

$$b_{\text{ext}} = 3*f(RH)*[(NH_4)_2SO_4] + 3*f(RH)*[NH_4NO3] + 4*[OC] + 1*[PM_f] + 0.6*[PM_c] + 10*[EC] + b_{Rav}$$

The algorithm will be used to calculate the daily light extinction attributable to La Cygne Unit 1 and Unit 2 and light extinction attributable to a natural background. The change in deciviews based on the source and background light extinctions will be evaluated using the equation below.

$$\Delta dv = 10*ln \left[\frac{b_{\text{ext, background}} + b_{\text{ext, source}}}{b_{\text{ext, background}}} \right]$$

5.2 CALPOST PROCESSING METHOD

KCP&L will use CALPOST Method 6, which calculates hourly light extinction impacts for the source and background using monthly average relative humidity adjustment factors. KCP&L will use monthly Class I area-specific relative humidity adjustment factors based on the centroid of the Class I areas as included in Table A-3 of EPA's *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Program*. The factors for the Class I areas in this analysis are provided in Table 5-1.

Class I Area	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Hercules-Glades	3.2	2.9	2.7	2.7	3.3	3.3	3.3	3.3	3.4	3.1	3.1	3.3
Wichita Mountains	2.7	2.6	2.4	2.4	3.0	2.7	2.3	2.5	2.9	2.6	2.7	2.8
Upper Buffalo	3.3	3.0	2.7	2.8	3.4	3.4	3.4	3.4	3.6	3.3	3.2	3.3
Caney Creek	3.4	3.1	2.9	3.0	3.6	3.6	3.4	3.4	3.6	3.5	3.4	3.5

TABLE 5-1. MONTHLY HUMIDITY FACTORS

Mingo

3.3

3.5

3.5

3.1

5.3 NATURAL BACKGROUND

KCP&L will use EPA's default average annual aerosol concentrations for the western half of the U.S. that are included in Table 2-1 of EPA's *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Program* for Wichita Mountains. KCP&L will use EPA's default average annual aerosol concentrations for the eastern half of the U.S. that are included in Table 2-1 of EPA's *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Program* for Upper Buffalo, Caney Creek, Hercules Glades and Mingo. The annual average concentrations are provided in Table 5-2.

TABLE 5-2. DEFAULT AVERAGE ANNUAL NATURAL BACKGROUND LEVELS

	Average Annual Natural Background – Western	Average Annual Natural Background – Eastern
Component	$(\mu g/m^3)$	(μg/m ³)
Ammonium Sulfate	0.12	0.23
Ammonium Nitrate	0.1	0.1
Organic Carbon Mass	0.47	1.4
Elemental Carbon	0.02	0.02
Soil	0.5	0.5
Coarse Mass	3	3

5.4 SUMMARY OF CALPOST CONTROL PARAMETERS

Table 5-3 provides a listing of the CALPOST parameters that KCP&L proposes to use in the modeling analysis. In addition to the parameters that will be used for the modeling, the table also lists CENRAP's recommended parameters for comparison. In cases where a parameter to be used is different than what CENRAP recommended, a short explanation as to the difference is proved.

TABLE 5-3. SUMMARY OF CALPOST INPUTS

CALPOST		Value Included in	Value KCP&L Will	
Variable	Description	CENRAP Protocol	Use	Notes
ISYR	Starting year	2001	Appropriate met	Years 2001, 2002,
			year	2003
ISMO	Starting month	1	1	
ISDY	Starting day	1	1	
ISHR	Starting hour	0	1	All CALPUFF periods will be included
NPER	Number of periods to process	8760	8760	
NREP	Process every hour of data? 1 = yes	1	1	
ASPEC	Process species for visibility	VISIB	VISIB	

CALPOST		Value Included in	Value KCP&L Will	
Variable	Description	CENRAP Protocol	Use	Notes
ILAYER	Layer/deposition code; 1 for CALPUFF concentrations	1	1	
A	Scaling factor, slope	0	0	
В	Scaling factor, intercept	0	0	
LBACK	Add hourly background concentrations of fluxes?	F	F	
LG	Process gridded receptors?	F	F	
LD	Process discrete receptors?	T	T	
LCT	Process complex terrain receptors?	F	F	
LDRING	Report receptor ring results?	F	F	
NDRECP	Select all discrete receptors	-1	Varies	As appropriate for Class I area being analyzed
IBGRID	X index of LL corner of receptor grid	-1	-1	
JBGRID	Y index of LL corner of receptor grid	-1	-1	
IEGRID	X index of UR corner of receptor grid	-1	-1	
JEGRID	Y index of UR corner of receptor grid	-1	-1	
NGONOFF	Number of gridded receptor rows	0	0	
NGXRECP	Exclude specific gridded receptors, Yes = 0	0	0	
RHMAX	Maximum RH% used in particle growth curve	95	95	
LVSO4	Compute light extinction for sulfate?	Т	Т	
LVNO3	Compute light extinction for nitrate?	Т	Т	
LVOC	Compute light extinction for organic carbon?	Т	Т	

CALPOST		Value Included in	Value KCP&L Will	
Variable	Description	CENRAP Protocol	Use	Notes
LVMPC	Compute light	T	T	110105
	extinction for	1	1	
	coarse particles?			
LVMPF	Compute light	Т	Т	
L VIVIII I	extinction for fine	1	1	
	particles?			
LVEC	Compute light	Т	Т	
LVLC	extinction for	1	1	
	elemental carbon?			
LVBK	Include background	Т	Т	
LVDK	in extinction	1	1	
	calculation?			
SPECPMC	Coarse particulate	PMC	PMC	
SPECIFIC	species	FIVIC	FIVIC	
SPECPMF		DM	PMF	Notation difference
SPECPMIF	Fine particulate species	PM ₁₀	PMF	Notation difference
EEDMC		0.6	0.6	
EEPMC	Extinction	0.6	0.6	
	efficiency for			
EED) (E	coarse particulates	1.0	1.0	
EEPMF	Extinction	1.0	1.0	
	efficiency for fine			
	particles?			
EEPMCBCK	Extinction	0.6	0.6	
	efficiency for			
	coarse part.			
	Background			
EESO4	Extinction	3.0	3.0	
	efficiency for			
	ammonium sulfate			
EENO3	Extinction	3.0	3.0	
	efficiency for			
	ammonium nitrate			
EEOC	Extinction	4.0	4.0	
	efficiency for			
	organic carbon			
EESOIL	Extinction	1.0	1.0	
	efficiency for soil			
EEEC	Extinction	10.0	10.0	
	efficiency for			
	elemental carbon			
MVISBK	Method 6 for	6	6	
	background light			
	extinction			
BEXTBTBK	Background	12	Not Used	Not necessary since
	extinction for			MVISBK=6
	MVISBK=1			
RHFRAC	% of particles	10	Not Used	Not necessary since
	affected by RH			MVISBK=6

CALPOST		Value Included in	Value KCP&L Will	
Variable	Description	CENRAP Protocol	Use	Notes
RHFAC	Extinction	Depends on Class I	See Table 5-1	As appropriate for
	coefficients for	Area		Class I area
	modeled and			
	background			
	hygroscopic species			
	computed using			
	EPA (2003)			
	monthly RH			
PMGOA	adjustment factors	0.12	0.12	TT 1C TT! 1'
BKSO4	Background sulfate	0.12	0.12	Used for Wichita
	extinction coeff - west			Mountains
BKNO3	Background nitrate	0.10	0.10	Used for Wichita
DKNOS	extinction coeff –	0.10	0.10	Mountains
	west			Wibuiltailis
BKPMC	Background coarse	3.00	3.00	Used for Wichita
DININIC	part. extinction	3.00	3.00	Mountains
	coeff – west			Wioditaling
BKSOC	Background	0.47	0.47	Used for Wichita
	organic carbon			Mountains
	extinction coeff –			
	west			
BKSOIL	Background soil	0.50	0.50	Used for Wichita
	extinction coeff -			Mountains
	west			
BKSEC	Background	0.02	0.02	Used for Wichita
	elemental carbon			Mountains
	extinction coeff –			
	west			
BKSO4	Background sulfate	0.23	0.23	Used for Upper
	extinction coeff –			Buffalo, Caney
	east			Creek, Hercules
BKNO3	Background nitrate	0.10	0.10	Glades and Mingo Used for Upper
DKNOS	extinction coeff –	0.10	0.10	Buffalo, Caney
	east			Creek, Hercules
	Cast			Glades and Mingo
BKPMC	Background sulfate	3.00	3.00	Used for Upper
	extinction coeff –		2.00	Buffalo, Caney
	west			Creek, Hercules
				Glades and Mingo
BKSOC	Background	1.40	1.40	Used for Upper
	organic carbon			Buffalo, Caney
	extinction coeff –			Creek, Hercules
	east			Glades and Mingo
BKSSOIL	Background soil	0.50	0.50	Used for Upper
	extinction coeff –			Buffalo, Caney
	east			Creek, Hercules
DIVOES	D 1 .	0.02	0.02	Glades and Mingo
BKSEC	Background	0.02	0.02	Used for Upper
	elemental carbon			Buffalo, Caney
	extinction coeff –			Creek, Hercules
	east	l		Glades and Mingo

CALPOST		Value Included in	Value KCP&L Will	
Variable	Description	CENRAP Protocol	Use	Notes
BEXTRAY	Extinction due to	10.0	10.0	- 12322
	Rayleigh scattering			
	(1/Mm)			
LDOC	Print documenta-	F	F	
	tion image?			
IPTRU	Print output units	3	1	Units preference
	for concentrations			
	and for deposition			
L1HR	Report 1 hr	F	F	
	averaging times			
L3HR	Report 3 hr	F	F	
	averaging times			
L24HR	Report 24 hr	T	T	
1 D1 D1	averaging times		7	
LRUNL	Report run-length	F	F	
1.00	averaging times	Г	Г	
LT50	Top 50 table	F	F	
LTOPN	Top N table	F	F	
NTOP	Number of Top-N values at each	4	4	
ITOP	receptor Ranks of Top-N	1 2 2 4	1 2 2 4	
110P	values at each	1,2,3,4	1,2,3,4	
	receptor			
LEXCD	Threshold	F	F	
LLACD	exceedances counts		1	
THRESH1	Averaging time	-1	-1	
TITALISTIT	threshold for 1 hr	1		
	averages			
THRESH3	Averaging time	-1	-1	
	threshold for 3 hr			
	averages			
THRESH24	Averaging time	-1	-0.2	Lower threshold –
	threshold for 24 hr			no effect on results
	averages			
THRESHN	Averaging time	-1	-1	
	threshold for			
ND 444	NAVG-hr averages			
NDAY	Accumulation	0	0	
NCOLINE	period, days	1	1	
NCOUNT	Number of exceedances	1	1	
	allowed			
LECHO	Echo option	F	F	
LTIME	Time series option	F	F	
LPLT	Plot file option	F	F	
LGRD	Use grid format	F	F	
LOND	instead of DATA	1	1	
	format			
LDEBUG	Output information	F	F	
	for debugging?	=	=	
		I	l .	<u> </u>

5.5 EVALUATING BART

KCP&L will perform modeling as outlined in this protocol to determine the visibility impacts based on the existing emission rates and exhaust characteristics for La Cygne Unit 1 and Unit 2. The modeling methods outlined in this protocol will also be used in the evaluation of BART control options. Since we are in the process of evaluating BART control options, specific data related to the control options are not provided in this protocol. KCP&L will provide data specific to the control options as part of the controls analysis.

GEOPHYSICAL DATA

TABLE A-1. LAND USE DATA USED IN ANALYSIS

1:250,000 Scale Data

Abilene Oklahoma City Ardmore Paducah Poplar Bluff Belleville Beloit Pratt Blytheville Quincy Rolla Clinton Dallas Sherman Decatur Shreveport Dyersburg Springfield El Dorado St. Louis Enid Texarkana Fort Smith Tulsa Great Bend Tupelo

Greenwood Tyler
Harrison West Point
Helena Wichita
Wichita Fel

Hutchinson Wichita Falls Jackson Woodward

Jefferson City

Joplin 1:100,000 Scale Data

Kansas City Antlers
Lawrence Conway
Lawton DeQueen

Little Rock Fly Gap Mountains

Manhattan McAlester Memphis Mena

Meridian Mountainview Moberly Russellville

TABLE A-2. TERRAIN DATA USED IN ANALYSIS

1:250,000 Scale Data

Abilene-E Hutchinson-E Pratt-E Pratt-W Abilene-W Hutchinson-W Ardmore-E Jackson-E Quincy-E Ardmore-W Jackson-W Quincy-W Belleville-E Jefferson City-E Rolla-E Rolla-W Belleville-W Jefferson City-W Beloit-E Joplin-E Russellville-E Beloit-W Joplin-W Russellville-W Kansas City-E Sherman-E Blytheville-E Blytheville-W Kansas City-W Sherman-W Clinton-E Lawrence-E Shreveport-E Clinton-W Lawrence-W Shreveport-W Dallas-E Lawton-E Springfield-E Dallas-W Lawton-W Springfield-W Decatur-E Little Rock-E Saint Louis-E Decatur-W Little Rock-W Saint Louis-W Dyersburg-E Manhattan-E Texarkana-E Dyersburg-W Manhattan-W Texarkana-W Tulsa-E El Dorado-E McAlester-E El Dorado-W McAlester-W Tulsa-W Enid-E Memphis-E Tupelo-E Enid-W Memphis-W Tupelo-W Fort Smith-E Meridian-E Tyler-E Meridian-W Tyler-W Fort Smith-W West Point-E Great Bend-E Moberly-E Great Bend-W Moberly-W West Point-W Greenwood-E Oklahoma City-E Wichita Falls-E Greenwood-W Oklahoma City-W Wichita Falls-W Harrison-E Paducah-E Wichita-E Harrison-W Paducah-W Wichita-W Helena-E Poplar Bluff-E Woodward-E Helena-W Poplar Bluff-W Woodward-W

TABLE B-1. LIST OF SURFACE METEOROLOGCAL STATIONS

Station						
ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
3927	DALLAS-FORT WORTH INTL AP	KDFW	32.900	-97.017	217.594	-110.664
3928	WICHITA MID-CONTINENT AP	KICT	37.650	-97.433	168.277	415.757
3945	COLUMBIA REGIONAL AIRPORT	KCOU	38.817	-92.217	616.499	566.49
3947	KANSAS CITY INT'L ARPT	KMCI	39.300	-94.717	397.998	606.872
13930	WHITEMAN AFB	KSZL	38.717	-93.550	502.081	547.665
13957	SHREVEPORT REGIONAL ARPT	KSHV	32.450	-93.817	518.947	-148.434
13959	WACO REGIONAL AP	KACT	31.617	-97.233	200.571	-253.861
13962	ABILENE REGIONAL AP	KABI	32.417	-99.683	-31.46	-166.963
13964	FORT SMITH REGIONAL AP	KFSM	35.333	-94.367	450.826	168.614
13966	WICHITA FALLS MUNICIPAL ARPT	KSPS	33.983	-98.500	78.106	7.4
13967	OKLAHOMA CITY WILL ROGERS WOR	KOKC	35.383	-97.600	158.172	163.934
13968	TULSA INTERNATIONAL AIRPORT	KTUL	36.200	-95.883	310.224	258.752
13969	PONCA CITY MUNICIPAL AP	KPNC	36.733	-97.100	199.91	314.65
13977	TEXARKANA WEBB FIELD	KTXK	33.450	-94.000	495.621	-38.391
13984	CONCORDIA BLOSSER MUNI AP	KCNK	39.550	-97.650	145.489	626.359
13989	EMPORIA MUNICIPAL AP	KEMP	38.333	-96.183	275.593	494.432
13995	SPRINGFIELD REGIONAL ARPT	KSGF	37.233	-93.383	526.725	384.127
13996	TOPEKA MUNICIPAL AP	KTOP	39.067	-95.633	320.318	577.594
72244	TYLER/POUNDS FLD	KTYR	32.350	-95.400	370.978	-166.863
72249	NACOGDOCHES (AWOS)	KOCH	31.583	-94.717	439.217	-249.285
72258	COX FLD	KPRX	33.633	-95.450	360.508	-24.527
72341	MEMORIAL FLD	KHOT	34.467	-93.100	571.592	79.365
72344	FAYETTEVILLE DRAKE FIELD	KFYV	36.000	-94.167	464.929	243.488
72349	JOPLIN MUNICIPAL AP	KJLN	37.150	-94.500	428.648	369.387
72352	ARDMORE	K1F0	34.150	-97.117	205.042	27.981
72445	KIRKSVILLE REGIONAL AP	KIRK	40.100	-92.550	577.7	706.619
72449	ST JOSEPH ROSECRANS MEMORIAL	KSTJ	39.767	-94.900	379.885	657.971
72450	CHANUTE MARTIN JOHNSON AP	KCNU	37.667	-95.483	339.483	422.786
72455	MANHATTAN RGNL	KMHK	39.133	-96.667	230.987	581.961
72458	SALINA MUNICIPAL AP	KSLN	38.817	-97.667	145.454	544.915
93950	MCALESTER MUNICIPAL AP	KMLC	34.900	-95.783	324.515	114.893
93986	HOBART MUNICIPAL AP	KHBR	35.000	-99.050	27.099	120.026
72439	QUINCY MUNICIPAL BALDWIN FLD	KUIN	39.900	-91.200	694.052	693.367
72439	SPRINGFIELD CAPITOL AP	KSPI	39.800	-89.600	831.037	694.973
72433	BELLEVILLE SCOTT AFB	KBLV	38.500	-89.800	828.344	549.557

Station						
ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
72531	KAHOKIA/ST. LOUIS	KCPS	38.500	-90.100	802.399	547.016
72445	JEFFERSON CITY MEM	KJEF	38.500	-92.100	629.243	532.143
72445	KAISER MEM	KAIZ	38.100	-92.500	597.734	485.303
72445	SEDALIA MEM	KDMO	38.700	-93.100	541.118	548.219
72445	VICHY ROLLA NATL APT	KVIH	38.100	-91.700	667.423	490.56
72445	FARMINGTON APT	KFAM	37.700	-90.400	784.689	456.128
72433	CARBONDALE	KMDH	37.700	-89.200	889.555	466.564
72348	CAPE GIRARDEAU MUNICIPAL APT	KCGI	37.200	-89.500	869.018	408.63
72435	PADUCAH BARKLEY REG AP	KPAH	37.000	-88.700	941.785	394.085
72330	POPLAR BLUFF	KPOF	36.700	-90.400	794.99	345.628
72334	DYERSBURG MUN AP	KDYR	36.000	-89.400	891.548	277.081
72340	WALNUT RIDGE	KARG	36.100	-90.900	756.52	275.288
72344	BATESVILLE	KBVX	35.700	-91.600	697.546	225.767
72340	JONESBORO MUNICIPAL APT	KJBR	35.800	-90.600	786.334	244.532
72334	JACKSON MCKELLAR-SIPES REGL	KMKL	35.600	-88.900	940.995	237.698
72334	MEMPHIS INTL APT	KMEM	35.000	-89.900	857.761	162.112
72341	STUTTGART	KSGT	34.600	-91.500	716.472	104.798
72341	PINE BLUFF/GRIDER	KPBF	34.100	-91.900	684.322	46.538
72340	LITTLE ROCK ADAMS FIELD	KLIT	34.700	-92.200	651.867	110.892
72340	LITTLE ROCK AFB	KLRF	34.900	-92.100	659.299	133.715
72344	FLIPPIN	KFLP	36.300	-92.400	620.853	286.681
72531	DECATUR	KDEC	39.800	-88.800	898.976	702.162
72433	MOUNT VERNON	KMVN	38.300	-88.800	917.197	536.538
72434	ST. LOUIS LAMBERT INTL APT	KSTL	38.700	-90.300	783.013	567.477

TABLE B-2. LIST OF PRECIPITATION METEOROLOGICAL STATIONS

Station ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
30130	ALUM FORK	ALUM	34.800	-92.850	591.935	117.768
30178	ANTOINE	ANTO	34.033	-93.417	545.626	29.461
30220	ARKADELPHIA 2 N	ARKA	34.150	-93.050	578.461	44.534
30764	BLAKELY MOUNTAIN DAM	BLAK	34.567	-93.200	561.75	89.82
30832	BOONEVILLE 3 SSE	BOON	35.100	-93.917	493.003	144.997
30900	BRIGGSVILLE	BRIG	34.933	-93.500	531.902	128.745
31152	CAMDEN 1	CAMD	33.600	-92.817	604.003	-14.996
31457	CLARKSVILLE 6 NE	CLAR	35.533	-93.400	536.873	195.774
31952	DE QUEEN DAM	DE Q	34.100	-94.367	457.937	31.902
32020	DIERKS DAM	DIER	34.150	-94.083	483.655	38.834
32544	FOREMAN	FORE	33.717	-94.383	458.602	-10.703
32574	FORT SMITH MU, OK	FORT	35.333	-94.367	450.855	168.653
33165	HARRISON BOONE CNTY AP	HARR	36.267	-93.157	553.576	278.374
34185	LEWISVILLE	LEWI	33.367	-93.567	536.29	-45.314

Station ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
34548	MAGNOLIA 3 N	MAGN	33.333	-93.250	565.86	-47.199
34756	MENA	MENA	34.567	-94.267	464.388	84.135
35200	NIMROD DAM	NIMR	34.950	-93.167	562.061	132.486
35228	NORFORK DAM	NORF	36.249	-92.256	634.101	282.023
35908	PRESCOTT	PRES	33.800	-93.383	550.293	3.781
37048	TEXARKANA	TEXA	33.450	-94.000	495.621	-38.391
37488	WALDRON	WALD	34.900	-94.100	477.588	121.905
140326	ARLINGTON	ARLI	37.900	-98.267	94.684	442.364
141233	CALDWELL	CALD	37.034	-97.616	153.468	347.056
141427	CHANUTE FAA AIRPORT	CHAN	37.670	-95.484	339.366	423.145
141767	CONCORDIA BLOSSER MUNI	CONC	39.551	-97.651	145.415	626.512
141867	COUNCIL GROVE LAKE	COUN	38.675	-96.526	244.636	531.493
143997	IONIA	IONI	39.661	-98.348	85.529	637.868
144341	KIOWA	KIOW	37.017	-98.485	76.494	344.138
145063	MARYSVILLE	MARY	39.833	-96.633	231.722	659.797
145306	MILFORD LAKE	MILF	39.075	-96.898	211.249	574.959
147160	SALINA AP	SALI	38.817	-97.667	145.454	544.915
148167	TOPEKA BILLARD MUNI AP	TOPE	39.069	-95.639	319.802	577.785
148293	UNIONTOWN	UNIO	37.848	-94.978	382.945	444.73
148830	WICHITA	WICH	37.650	-97.433	168.277	415.757
165874	MANSFIELD	MANS	32.033	-93.700	532.631	-194.082
166244	MINDEN	MIND	32.600	-93.300	566.346	-128.864
166582	NATCHITOCHES	NATC	31.767	-93.100	591.063	-220.21
167738	RED RIVER RSRCH STN	RED	32.417	-93.633	536.38	-151.129
168440	SHREVEPORT, LA	SHRE	32.467	-94.317	472.014	-149.154
230204	APPLETON CITY	APPL	38.184	-94.026	464.144	486.148
230789	BOLIVAR 1 NE	BOLI	37.617	-93.391	523.377	426.582
231383	CASSVILLE RANGER STN	CASS	36.673	-93.858	488.393	319.564
231791	COLUMBIA REGIONAL AP	COLU	38.817	-92.218	616.384	566.475
232302	DORA	DORA	36.780	-92.233	631.838	340.862
234315	JOPLIN REGIONAL AP	JOPL	37.147	-94.502	428.471	369.008
234358	KANSAS CITY AP	KANS	39.300	-94.717	397.998	606.872
234544	KIRKSVILLE	KIRK	40.200	-92.567	575.475	717.609
234825	LEBANON 2 W	LEBA	37.685	-92.694	584.043	438.162
235834	MOUNTAIN GROVE 2 N	MOUN	37.153	-92.264	626.06	381.947
235987	NEVADA WATER PLANT	NEVA	37.839	-94.373	435.885	446.376
237976	SPRINGFIELD REG AP	SPRI	37.240	-93.390	526.086	384.835
238252	TABLE ROCK DAM	TABL	36.597	-93.308	537.808	314.127
238466	TRUMAN DAM & RESERVIOR	TRUM	38.258	-93.399	518.297	497.601
340179	ALTUS IRIG RES STN	ALTU	34.583	-99.333	1.342	73.726
340215	AMES	AMES	36.250	-98.183	104.257	259.348
340292	ARDMORE	ARDM	34.167	-97.133	203.499	29.797

Station ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
340670	BENGAL	BENG	34.850	-95.083	388.412	111.938
341437	CANEY	CANE	34.233	-96.217	287.462	39.536
341544	CARTER TOWER	CART	34.267	-94.783	418.786	48.493
341684	CHANDLER 1	CHAN	35.700	-96.883	222.108	200.524
341750	CHICKASHA EXP STN	CHIC	35.050	-97.917	130.07	126.502
342334	CUSTER CITY	CUST	35.650	-98.833	46.415	192.255
342654	DUNCAN AIRPORT	DUNC	34.483	-97.967	126.429	63.529
342849	ELK CITY	ELK	35.383	-99.400	-4.705	162.536
343281	FORT COBB	FORT	35.100	-98.433	83.068	131.48
343497	GEARY	GEAR	35.633	-98.317	93.029	190.78
344052	HENNEPIN 5 N	HENN	34.567	-97.350	182.671	73.771
344202	HOBART	HOBA	35.033	-99.083	24.058	123.718
344865	KINGSTON	KING	34.000	-96.733	240.748	12.214
344975	LAKE EUFAULA	LAKE	35.283	-95.433	354.598	158.646
345108	LEHIGH	LEHI	34.467	-96.217	286.619	65.434
345463	MACKIE 4 NNW	MACK	35.750	-99.833	-43.712	203.34
345589	MARSHALL	MARS	36.150	-97.617	155.133	249.015
345664	MCALESTER MUNI AP	MCAL	34.883	-95.783	324.554	113.043
346130	MUSKOGEE	MUSK	35.767	-95.333	361.415	212.616
346620	OKARCHE	OKAR	35.717	-97.983	122.963	200.402
346638	OKEMAH	OKEM	35.433	-96.300	275.597	172.448
346661	OKLAHOMA CITY, OK	OKLA	35.383	-97.600	158.171	163.971
347196	PONCA CITY	PONC	36.717	-97.100	199.951	312.875
347705	ROFF 2 WNW	ROFF	34.633	-96.883	225.139	82.16
348992	TULSA INTL AIRPORT	TULS	36.198	-95.888	309.803	258.552
349023	TUSKAHOMA	TUSK	34.633	-95.283	371.223	87.116
349629	WICHITA MTN WL REF	WICH	34.733	-98.717	57.604	90.569
349724	WISTER	WIST	34.950	-94.700	422.763	124.642
349748	WOLF 4 N	WOLF	35.133	-96.667	243.38	138.175
410016	ABILENE MUN, TX	ABIL	32.417	-99.683	-31.492	-167
410926	BONITA 4 NW	BONI	33.833	-97.633	158.221	-8.161
411246	BURLESON	BURL	32.550	-97.317	190.447	-150.213
411698	CHILDRESS MUNI AP	CHIL	34.433	-100.283	-85.662	57.486
411773	CLARKSVILLE 1 W	CLAR	33.617	-95.017	400.641	-24.627
411921	COMMERCE	COMM	33.200	-95.933	317.534	-74.315
412086	CRANFILLS GAP	CRAN	31.767	-97.833	143.384	-238.27
412096	CRESSON	CRES	32.533	-97.617	162.357	-152.616
412131	CROSS PLAINS 2	CROS	32.133	-99.167	17.09	-198.565
412242	DALLAS-FORT WORTH/FORT. TX.	DALL	32.900	-97.017	217.625	-110.663
412244	DALLAS LOVE FIELD	DALL	32.850	-96.850	233.324	-115.831
412404	DENTON 2 SE	DENT	33.200	-97.100	209.069	-77.506
412715	EASTLAND	EAST	32.400	-98.817	49.911	-168.771

Station ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
413133	FERRIS	FERR	32.517	-96.667	251.477	-152.428
413285	FORT WORTH WSFO	FORT	32.833	-97.300	191.339	-118.676
413415	GAINESVILLE	GAIN	33.633	-97.133	204.862	-29.433
413546	GILMER 2 W	GILM	32.733	-94.983	408.173	-122.577
413642	GORDONVILLE	GORD	33.800	-96.850	230.585	-10.281
413771	GROESBECK 2	GROE	31.533	-96.533	267.178	-261.477
414137	HICO	HICO	31.983	-98.033	124.123	-214.429
414257	HONEY GROVE	HONE	33.583	-95.900	319.106	-31.63
414520	JACKSBORO 1 NNE	JACK	33.233	-98.150	111.378	-75.549
414866	KOPPERL	KOPP	32.133	-97.483	175.721	-196.88
414972	LAKE BRIDGEPORT DAM	LAKE	33.217	-97.833	140.846	-76.986
415348	LONGVIEW TX.	LONG	32.350	-94.650	441.401	-163.699
415463	MABANK 4 SW	MABA	32.350	-96.117	303.664	-169.375
415957	MINERAL WELLS 1 SSW	MINE	32.783	-98.117	115.117	-125.535
415996	MOLINE	MOLI	31.400	-98.317	98.07	-279.711
416108	MOUNT PLEASANT	MOUN	33.167	-95.000	404.44	-74.517
416177	NACOGDOCHES	NACO	31.617	-94.650	445.383	-245.232
416210	NAVARRO MILLS DAM	NAVA	31.950	-96.700	250.085	-215.548
416270	NEW BOSTON	NEW	33.450	-94.417	457.042	-40.453
416335	NEW SUMMERFIELD 2 W	NEW	31.983	-95.133	397.806	-206.567
416757	PALESTINE 2 NE	PALE	31.783	-95.600	354.65	-230.638
416834	PAT MAYSE DAM	PAT	33.867	-95.517	353.313	1.165
417066	PITTSBURG 5 S	PITT	32.933	-94.933	411.826	-100.148
417300	PROCTOR RESERVOIR	PROC	31.967	-98.500	80.081	-216.779
417499	RED SPRINGS 2 ESE	RED	33.600	-99.383	-3.269	-35.493
417556	RENO	RENO	32.950	-97.567	166.188	-106.202
418047	SANTA ANNA	SANT	31.750	-99.333	1.39	-241.254
418583	STAMFORD 1	STAM	32.933	-99.800	-42.179	-109.493
418623	STEPHENVILLE 1 N	STEP	32.250	-98.200	108.034	-184.954
418743	SULPHUR SPRINGS	SULP	33.150	-95.633	345.632	-78.835
418778	SWAN	SWAN	32.450	-95.417	368.959	-155.811
419163	TRUSCOTT	TRUS	33.750	-99.867	-47.911	-18.699
419419	WACOMADISON-COOPER TX.	WACO	31.617	-97.233	200.54	-253.899
419532	WEATHERFORD	WEAT	32.750	-97.767	147.896	-128.764
419565	WELLINGTON	WELL	34.833	-100.217	-79.156	101.839
419715	WHITNEY DAM	WHIT	31.850	-97.367	187.363	-228.192
419729	WICHITA FALLS/SHEPS AFB TX	WICH	33.983	-98.500	78.106	7.437
419817	WINCHELL	WINC	31.467	-99.167	17.23	-272.793
419893	WOODSON	WOOD	33.017	-99.050	27.781	-100.284
419916	WRIGHT PATMAN	WRIG	33.300	-94.167	481.088	-55.882
118179	SPRINGFIELD	SPRI	39.850	-89.680	823.683	699.815
114442	JACKSONVILLE	JACK	39.730	-90.200	780.783	682.207

Station ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
116837	PITTSFIELD	PITT	39.610	-90.800	730.895	664.216
231640	CLARKSVILLE L&D	CLAR	39.360	-90.900	724.802	635.788
113666	GREENFIELD	GREE	39.350	-90.210	783.935	640.088
111284	CARLINVILLE	CARL	39.280	-89.880	812.919	635.084
115841	MORRISONVILLE	MORR	39.410	-89.460	847.375	653.077
111290	CARLYLE RESERVOIR	CARL	38.630	-89.360	864.887	567.788
118147	SPARTA	SPAR	38.110	-89.710	840.454	507.252
115983	MURPHYSBORO	MURP	37.760	-89.360	874.891	471.721
233601	HANNIBAL WATER WORKS	HANN	39.710	-91.360	682.205	671.178
231600	CLARENCE CANNON DAM	CLAR	39.530	-91.630	660.799	649.357
235050	LONG BRANCH RESERVOIR	LONG	39.750	-92.510	583.855	668.049
235671	MOBERLY	MOBE	39.400	-92.430	593.467	629.742
236012	NEW FRANKLIN	NEW	39.010	-92.750	569.027	584.59
233079	FULTON	FULT	38.850	-91.930	640.981	572.019
231283	CAP AU GRIS	CAP	39.000	-90.680	747.223	597.635
238746	WASHINGTON	WASH	38.550	-90.980	725.766	545.56
237300	ROSEBUD	ROSE	38.450	-91.380	692.073	531.55
237263	ROLLA UNIV OF MO	ROLL	37.950	-91.780	661.764	473.409
238620	VIENNA	VIEN	38.200	-91.980	642.188	499.724
238043	STEELVILLE	STEE	38.000	-91.360	697.947	481.907
236826	POTOSI	РОТО	37.960	-90.760	750.633	481.998
238609	VIBURNUM	VIBU	37.710	-91.130	720.74	451.526
237506	SALEM	SALE	37.550	-91.880	656.478	428.461
230088	ALLEY SPRINGS	ALLE	37.150	-91.450	697.833	387.234
231674	CLEARWATER DAM	CLEA	37.130	-90.760	758.841	390.244
232809	FARMINGTON	FARM	37.800	-90.410	782.785	467.099
230022	ADVANCE	ADVA	37.100	-89.900	834.924	394.048
238700	WAPPAPELLO DAM	WAPP	36.930	-90.280	803.219	372.036
238880	WEST PLAINS	WEST	36.750	-91.830	667.791	340.292
232302	DORA	DORA	36.780	-92.230	632.081	340.911
235207	MALDEN MUNICIPAL	MALD	36.610	-89.980	833.16	339.238
233999	HORNERSVILLE	HORN	36.050	-90.110	827.589	276.263
220237	ARKABUTLA DAM, MS	ARKA	34.450	-90.080	847.34	99.742
221314	CALHOUN CITY 2 NW	CALH	33.520	-89.210	937.459	5.027
221707	CLARKSDALE	CLAR	34.120	-90.340	827.064	60.998
221743	CLEVELAND 3 N	CLEV	33.480	-90.430	825.402	-10.568
223650	GRENADA DAM	GREN	33.480	-89.460	914.88	-1.8
224001	HICKORY FLAT	HICK	34.370	-89.110	936.648	99.892
224173	HOLLY SPRINGS 4 N	HOLL	34.490	-89.260	921.582	111.695
226084	MOUNT PLEASANT 4 SW	MOUN	34.540	-89.330	914.634	116.549
227820	SAREPTA 1 NNE	SARE	34.070	-89.180	933.781	66.081
229079	UNIVERSITY, MS	UNIV	34.230	-89.320	919.123	82.406

				1	1	
Station ID	Name	ID	Latitude	Longitude	X (km)	Y (km)
400876	BOLIVAR WATERWORKS, TN	BOLI	35.160	-88.590	974.247	192.241
401150	BROWNSVILLE SEWAGE P	BROW	35.350	-89.160	920.598	207.596
403697	GREENFIELD	GREE	36.100	-88.470	973.304	297.122
404556	JACKSON MCKELLAR-SIP	JACK	35.360	-88.550	975.369	214.706
404561	JACKSON EXP STA	JACK	35.370	-88.500	979.742	216.317
405720	MASON	MASO	35.240	-89.320	907.463	193.934
405954	MEMPHIS INTL ARPT	MEMP	35.030	-90.000	848.388	164.54
405956	MEMPHIS WSFO	MEMP	35.080	-89.480	894.852	174.771
406358	MUNFORD	MUNF	35.270	-89.490	891.793	195.658
406750	OAK RIDGE	OAK	36.000	-84.150	1358.823	338.461
408065	SAMBURG WILDLIFE REF	SAMB	36.270	-89.190	907.143	308.843
409219	UNION CITY, TN	UNIO	36.240	-89.020	922.623	307.148
30064	ALICIA, AR	ALIC	35.540	-91.050	748.472	212.202
30458	BATESVILLE LIVESTOCK	BATE	35.500	-91.460	711.939	204.668
30530	BEEBE	BEEB	35.040	-91.540	708.871	153.189
30936	BRINKLEY	BRIN	34.530	-91.110	752.656	100.029
31632	CORNING	CORN	36.260	-90.350	803.976	297.429
32148	DUMAS	DUMA	33.530	-91.290	745.537	-12.05
32978	GREERS FERRY DAM	GREE	35.310	-92.000	664.907	179.784
33132	HARDY	HARD	36.170	-91.280	721.923	280.109
34900	MONTICELLO 3 SW	MONT	33.360	-91.480	729.54	-32.333
35754	PINE BLUFF	PINE	34.140	-92.010	673.896	50.191
36920	STUTTGART 9 ESE	STUT	34.280	-91.250	742.228	71.28
38052	WYNNE, AR	WYNN	35.150	-90.480	803.727	173.682

DETAILED EMISSION CALCULATIONS

Table C-1. Model Inputs Summary

Gas Temperatur e	ⅎ	127	281
Exit Velocity	ft/sec	92.7	100.8
Stack Diameter	¥	23.0	24.0
GEP Stack Height	¥	591.2	8.765
Stack Ht.	ij.	002	002
Longitude NAD83	dec. deg.	-94.646	-94.646
Latitude NAD83	dec. deg.	38.349	38.348
Base Elevation	Ħ	850	820
Source Name		La Cygne - Unit 1	La Cygne - Unit 2

	EC	0.22	0.98
	SOA	8.59	7.03
ej.	PM₊	5.68	25.58
Input to CALPUFF Hourly Mass Emission Rate <u>Ib/hr</u>	PM_{C}	4.92	33.20
Input to C ourly Mass <u>Ib</u>	SO ₄	34.37	28.12
I	PM ₁₀	53.79	94.92
	×ON	6,151.15 11,589.52	8,316.15 3,543.47
	${ m SO}_{ m S}$	6,151.15	8,316.15
tual 2-2004	PM ₁₀	99.0	1.14
Highest 24 hr Actual ission Rate [¶] 2002-2004 ton/24 hr	XON	139.07	42.52
High∉ Emissior	SO_2	73.81	99.79
BART-Eligible Source Name		La Cygne - Unit 1	La Cygne - Unit 2

usage data (the maximum daily heat input from 2002-2004, the minimum annual average fuel heat content from 2002-2004, the maximum annual average ash content from 2002 to 2004, and the maximum annual average The Highest 24-hr Actual Mass Emission Rates of SO₂ and NO_x are determined from actual monitored data from 2002-2004. The Highest 24-hr Actual Mass Emission Rate of PM₁₀ is calculated based on actual fuel sulfur content from 2002-2004) and AP-42 emission factors (see Table C-2).

24-Hr Fuel Usage

	Maximum 24-Hr	Maximum 24-Hr
	Coal Usage	Heat Input
	(ton/24hr)	(MMBtu/24hr)
La Cygne 1	12,806	223,488
La Cygne 2	11.739	198.911

The maximum daily coal usage is calculated by dividing the maximum daily heat input from 2002-2004 by the minimum of the annual average heat contents from 2002-2004.

PM10 Filterable and Condensable Emission Factors

							Sulfur		Control	Control
	PM10 Filterable	Emission Factor	Emission Factor	Emission Factor PM10 Condensible			Content§	Ash Content¥	Efficiency	Efficiency
	Emission Factor*	Units	Source	Emission Factor**	Units	Source	(%)	(%)	Filterable	Condensable
La Cygne 1	2.17	lb/ton	AP-42 Table 1.1-4	0.02	Ib/MMBtu	AP-42 Table 1.1-5	1.21	8.35	%96	%96
La Cygne 2	12.63	lb/ton	AP-42 Table 1.1-4	0.004	Ib/MMBtu	AP-42 Table 1.1-5	0.34	5.49	%66	%0
*PM10 filterable err	nission factors are for "Cyck	one furnace" boiler (La Cyg	ne 1) and "PC-fired, dry bo	M10 filterable emission factors are for "Cyclone furnace" boiler (La Cygne 1) and "PC-fired, dry bottom, wall-fired" boiler" (La Cygne 2).	ygne 2).					
** PM10 condensab	the emission factor for La Cy	ygne 1 is for PC boiler with	FGD control; the factor for I	*PM10 condensable emission factor for La Cygne 1 is for PC boiler with FGD control; the factor for La Cygne 2 is for PC boiler without FGD control.	vithout FGD control.					
§The coal sulfur co.	ntent is the maximum of the	The coal sulfur content is the maximum of the annual average sulfur contents from 2002-2004.	tents from 2002-2004.							
¥The coal ash cont	ent is the maximum of the	¥The coal ash content is the maximum of the annual average ash contents from 2002-2004.	ts from 2002-2004.							

24-Hr Emissions

	Total PM10	(Controlled)	(lb/24-hr)	1,291	2.278
PM10 Condensable	Emissions	(Controlled)	(lb/24-hr)	179	962
PM10 Filterable	Emissions	(Controlled)	(lb/24-hr)	1,112	1.482
	Total PM10	(Uncontrolled)	(lb/24-hr)	32,271	149.028
PM10 Condensable	24-Hr Emissions	(Uncontrolled)	(lb/24-hr)	4,470	962
PM10 Filterable 24- PM10 Condensabl	Hr Emissions	(Uncontrolled)	(lb/24-hr)	27,802	148.232
				La Cygne 1	La Cvane 2

Hourly Emissions (Based on 24-hr emissions divided by 24hrs)

PM10 Filterable 24- PM10 Condensable	PM10 Condensable			PM10 Filterable	PM10 Condensable	
Hr Emissions 24-Hr Emissions	24-Hr Emissions		Total PM10	Emissions	Emissions	Total PM10
(Uncontrolled) (Uncontrolled)	(Uncontrolled)	_	(Uncontrolled)	(Controlled)	(Controlled)	(Controlled)
(lb/hr) (lb/hr)	(lb/hr)		(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)
1,158 186	186		1,345	46	7	54
6.176 33	33		6.209	79	33.15	92

The maximum daily heat input is the maximum daily heat input from the years 2002-2004.

Controlled PM10 Speciation from AP-42 Tables 1.1-5 & 1.1-8 Cyclone Furnace w FGD + ESP for Emissions control

assumes	assumes heating value of		8,794 Btu/lb and a sulfur content of	ılfur cont	ent of	1.03	% and	1.03 % and an ash content of		8.05 % and a heat in	9,312	9,312 mmBtu/hr and f(RH) =	= (H	-
						Controlle	d PM10	Controlled PM10 Emissions (Bold values from Table 1.1-5.)	values fron	1 Table 1.1-5.)				
Boiler	Total PM10	Filterable	Coarse	Ext.	Fine	Fine Soil	Ext.	Fine EC	Ext.	Condensible	CPM IOR	Particle	CPM OR	Particle
Type	(lb/mmBtu)	(lb/mmBtu)	(Ib/mmBtu)	Coef.	(lb/mmBtu)	(lb/ton)	Coef.	(Ib/mmBtu)	Coef.	(Ib/mmBtu)	(lb/mmBtu)	Type Ext.Coef.	(lb/mmBtu)	Type Ext.Coef.
Cyclone	0.0250	0.0050	0.0023	9.0	0.0027	0.00265	1	0.00010	10	0.020	0.016	SO4 3*f(RH)	0.004	SOA 4
						Controlle	d PM10	Controlled PM10 Emissions (Bold Values from Table 1.1-8.)	Values fron	า Table 1.1-8.)				
Boiler	Total PM10	Filterable	Coarse	Ext.	Fine	Fine Soil	Ext.	Fine EC	Ext.	Condensible	CPM IOR	Particle	CPM OR	Particle
Type	(lb/ton)	(lb/ton)	(lb/ton)	Coef.	(lb/ton)	(lb/ton)	Coef.	(lb/ton)	Coef.	(lb/ton)	(lb/ton)	Type Ext.Coef.	(lb/ton)	Type Ext.Coef.
Cyclone	0.440	0.089	0.040	9.0	0.048	0.0465	-	0.0018	10	0.352	0.281	SO4 3*f(RH)	0.070	SOA 4
)	Controlled PM10 Emissions	missions					
Boiler	Total PM10	Filterable	Coarse	Ext.	Fine	Fine Soil	Ext.	Fine EC	Ext.	Condensible	CPM IOR	Particle	CPM OR	Particle
Type	(% of Total)	(% of Total)	(% of Total)	Coef.	(% of Total)	(% of Total)	Coef.	(% of Total)	Coef.	(% of Total)	(% of Total)	Type Ext.Coef.	(% of Total)	Type Ext.Coef.
Cyclone	100%	20.1%	9.1%	9.0	11.0%	10.6%	1	0.4%	10	%6.67	%6:89	SO4 3*f(RH)	16.0%	SOA 4

L	714	: ° C	! L	77.1		- 4 - 2 - 1 L	T-4-1 DM 140	٥٠٠٥	
10 Er	Md þ	Controlle							
					s in lb/hr:	110 emission	you are given Total PM10 emissions in Ib/hr:	It you are	

				2.8						
	Particle	Type Ext.Coef.	4	34.4						
	Pe	Type	SOA							
	CPM OR	(lb/hr)	8.6							
	Particle	Type Ext.Coef.	SO4 3	103.1						
	CPM IOR	(lb/hr)	34.4							
put by user.)	Condensible	(lb/hr)	43.0							
l Value is ir	Ext.	Coef.	10	2.2						
Controlled PM10 Emissions (Bold Value is Input by user.	Fine EC	(lb/hr)	0.22							
ed PM10	Ext.	Coef.	1	2.7	•	_	٥.	-	~	ω.
Control	Fine Soil	(lb/hr)	2.68		4.9	5.7	0.2	34.4	8	53.8
	Fine	(lb/hr)	2.90		Coarse	Fine Soil	Fine EC	CPM IOR	CPM OR	
	Ext.	Coef.	9.0	3.0						
	Coarse	(Jy/qI)	4.92	tinction						
	Filterable	(lb/hr)	10.82	Weighted Ex						
	Total PM10	(lb/hr)	53.8		9.1%	10.6%	0.4%	63.9%	16.0%	100.0%
	Boiler	Type	Cyclone		Coarse	Fine Soil	Fine EC	CPM IOR	CPM OR	

Controlled PM10 Speciation from AP-42 Tables 1.1-5 & 1.1-6
Dry Bottom Boiler burning Pulverized Coal using only ESP for Emissions control

assumes	assumes heating value of		8596 Btu/lb and a sulfur content of	fur conte	ent of	0.33	% and	an ash content of	5.41 %	0.33 % and an ash content of 5.41 % and a heat input o		8,288 mmBtu/hr and f(RH) =	H) =	-
						Control	lled PM	Controlled PM10 Emissions (Bold values from Table 1.1-5.	ld values fr	om Table 1.1-5.)				
Boiler	Total PM10	Filterable	Coarse	Ext.	Fine	Fine Soil	Ext.	Fine EC	Ext.	Condensible	CPM IOR	Particle	CPM OR	Particle
Type	(lb/mmBtu)	(lb/mmBtu)	(lb/mmBtu)	Coef.	(lb/mmBtu)	(lb/ton)	Coef.	(Ib/mmBtu)	Coef.	(lb/mmBtu)	(lb/mmBtu)	Type Ext.Coef.	(Ib/mmBtu)	Type Ext.Coef.
PC-DB	0.0270	0.0170	0.0094	9.0	0.0076	0.0073	1	0.0003	10	0.010	0.008	SO4 3*f(RH)	0.002	SOA 4
						Control	lled PM	Controlled PM10 Emissions (Bold Values from Table 1.1-6.)	d Values fr	om Table 1.1-6.)				
Boiler	Total PM10	Filterable	Coarse	Ext.	Fine	Fine Soil	Ext.	Fine EC	Ext.	Condensible	CPM IOR	Particle	CPM OR	Particle
Type	(lb/ton)	(lb/ton)	(lb/ton)	Coef.	(lb/ton)	(lb/ton)	Coef.	(uot/qI)	Coef.	(lb/ton)	(lb/ton)	Type Ext.Coef.	(lb/ton)	Type Ext.Coef.
PC-DB	0.464	0.292	0.162	9.0	0.130	0.125	1	0.005	10	0.172	0.138	SO4 3*f(RH)	0.034	SOA 4
								Controlled PM10 Emissions) Emissions					
Boiler	Total PM10	Filterable	Coarse	Ext.	Fine	Fine Soil	Ext.	Fine EC	Ext.	Condensible	CPM IOR	Particle	CPM OR	Particle
Type	(% of Total)	(% of Total)	(% of Total)	Coef.	(% of Total)	(% of Total)	Coef.	(% of Total)	Coef.	(% of Total)	(% of Total)	Type Ext.Coef.	(% of Total)	Type Ext.Coef.
PC-DB	100%	63.0%	32.0%	9.0	28.0%	%6.92	1	1.0%	10	37.0%	29.6%	SO4 3*f(RH)	7.4%	SOA 4

	•		
		1	
	The same contract of the same	١	
	5		
	-	1	

		ЭĘ.		Ī						
	Particle	Type Ext.Coef.	4	28.1						
	Ьа	Type	SOA							
	CPM OR	(lb/hr)	7.0							
	Particle	Type Ext.Coef.	SO4 3	84.4						
	CPM IOR	(lb/hr)	28.1							
Controlled PIMTU Emissions (Bold Value is Input by user.)	Condensible	(lp/hr)	35.2							
old value is i	Ext.	Coef.	10	8.6						
, Emissions (e	Fine EC	(lb/hr)	1.0							
lled PMTC	Ext.	Coef.	1	25.6						
Contro	Fine Soil	(IP/Pr)	25.6		33.2	25.6	1.0	28.1	7.0	94.9
	Fine	(lb/hr)	26.6		Coarse	Fine Soil	Fine EC	CPM IOR	CPM OR	
	Ext.	Coef.	9.0	19.9			_			
	Coarse	(lb/hr)	33.2	inction						
	Filterable	(lb/hr)	8.65	Weighted Extinction						
	Total PM10	(lb/hr)	94.9		35.0%	26.9%	1.0%	29.6%	7.4%	100.0%
	Boiler	Type	PC-DB		Coarse	Fine Soil	Fine EC	CPM IOR	CPM OR	

1.8

RECEPTOR DATA

Receptor	Latitude	Longitude	Elevation
receptor	(deg)	(deg)	(m)
1	36.654	-92.946	274
2	36.654	-92.938	299
3	36.654	-92.929	328
4	36.654	-92.929	365
5	36.663	-92.963	250
6	36.663	-92.954	278
7	36.663	-92.946	335
8	36.663	-92.938	307
9	36.663	-92.929	345
10	36.671	-92.971	261
11	36.671	-92.963	271
12	36.671	-92.954	274
13	36.671	-92.946	331
14	36.671	-92.938	327
15	36.671	-92.929	304
16	36.671	-92.921	335
17	36.671	-92.921	312
18	36.671	-92.904	340
19	36.671	-92.896	361
20	36.671	-92.888	382
21	36.679	-92.971	274
22	36.679	-92.963	274
23	36.679	-92.954	335
24	36.679	-92.946	294
25	36.679	-92.938	304
26	36.679	-92.929	279
27	36.679	-92.921	304
28	36.679	-92.913	318
29	36.679	-92.904	335
30	36.679	-92.896	347
31	36.679	-92.888	340
32	36.688	-92.954	247
33	36.688	-92.946	271
34	36.688	-92.938	275
35	36.688	-92.929	274
36	36.688	-92.921	277
37	36.688	-92.913	304
38	36.688	-92.904	330
39	36.688	-92.896	357
40	36.688	-92.888	384
41	36.688	-92.879	372
42	36.696	-92.979	274
43	36.696	-92.971	293
44	36.696	-92.963	272
45	36.696	-92.954	271
46	36.696	-92.946	274
		-92.938	
47	36.696	-92.938	327

Receptor	Latitude	Longitude	Elevation
	(deg)	(deg)	(m)
48	36.696	-92.929	316
49	36.696	-92.921	304
50	36.696	-92.913	354
51	36.696	-92.904	346
52	36.696	-92.896	335
53	36.696	-92.888	344
54	36.696	-92.879	364
55	36.704	-92.971	243
56	36.704	-92.963	335
57	36.704	-92.954	324
58	36.704	-92.946	335
59	36.704	-92.938	341
60	36.704	-92.929	333
61	36.704	-92.921	306
62	36.704	-92.913	304
63	36.704	-92.904	365
64	36.704	-92.896	304
65	36.704	-92.888	309
66	36.704	-92.879	307
67	36.713	-92.971	270
68	36.713	-92.963	274
69	36.713	-92.954	301
70	36.713	-92.946	274
71	36.713	-92.938	274
72 73	36.713	-92.929	312 274
74	36.713	-92.921	
	36.713	-92.913	322
75 76	36.713	-92.904	304
77	36.713	-92.896	275 304
78	36.713	-92.888 02.870	290
79	36.713 36.721	-92.879 -92.913	249
80	36.721	-92.913	274
81	34.704	-92.904	454
82	34.704	-98.746	486
83	34.704	-98.738	487
84	34.704	-98.729	478
85	34.704	-98.729	518
86	34.704	-98.713	518
87	34.713	-98.771	510
88	34.713	-98.763	493
89	34.713	-98.754	488
90	34.713	-98.746	615
91	34.713	-98.738	522
92	34.713	-98.729	494
93	34.713	-98.721	609
94	34.713	-98.713	518
95	34.721	-98.779	487
96	34.721	-98.771	518
97	34.721	-98.763	609
98	34.721	-98.754	554
99	34.721	-98.746	578
100	34.721	-98.738	557
101	34.721	-98.729	571

Receptor	Latitude	Longitude	Elevation
	(deg)	(deg)	(m)
102	34.721	-98.721	670
103	34.721	-98.713	518
104	34.729	-98.763	518
105	34.729	-98.754	548
106	34.729	-98.746	548
107	34.729	-98.738	518
108	34.738	-98.763	517
109	34.738	-98.754	579
110	34.738	-98.746	613
111	34.738	-98.738	548
112	34.738	-98.729	523
113	34.746	-98.771	542
114	34.746	-98.763	545
115	34.746	-98.754	552
116	34.771	-98.679	579
117	34.779	-98.713	609
118	34.779	-98.704	654
119	34.779	-98.696	621
120	34.779	-98.688	629
121	34.779	-98.679	579
122	34.779	-98.671	560
123	34.788	-98.721	615
124	34.788	-98.713	641
125	34.788	-98.704	640
126	34.788	-98.696	662
127	34.788	-98.688	618
128	34.788	-98.679	630
129	34.788	-98.671	534
130	34.796	-98.721	606
131	34.796	-98.713	566
132	34.796	-98.704	633
133	34.796	-98.696	670
134	34.796	-98.688	609
135	34.796	-98.679	579
136	34.796	-98.671	535
137	34.804	-98.704	548
138	34.804	-98.696	518
139	34.804	-98.688	506
140	35.821	-93.454	555
141	35.821	-93.446	589
142	35.821	-93.421	563
143	35.829	-93.454	549
144	35.829	-93.446	487
145	35.829	-93.438	487
146	35.829	-93.429	490
147	35.838	-93.454	650
148 149	35.838	-93.446 -93.438	563 540
150	35.838 35.838	-93.438 -93.429	502
150	35.838	-93.429 -93.421	526
151	35.838	-93.421	534
153	35.838	-93.404	563
154	35.846	-93.454	548
155	35.846	-93.446	628
133	22.010	75,110	020

Receptor	Latitude	Longitude	Elevation
•	(deg)	(deg)	(m)
156	35.846	-93.438	623
157	35.846	-93.429	579
158	35.846	-93.421	469
159	35.846	-93.413	457
160	35.846	-93.404	573
161	35.846	-93.396	605
162	35.846	-93.388	588
163	35.854	-93.454	608
164	35.854	-93.446	660
165	35.854	-93.438	598
166	35.854	-93.429	599
167	35.854	-93.421	639
168	35.854	-93.413	457
169	35.854	-93.404	568
170	35.863	-93.454	730
171	35.863	-93.446	681
172	35.863	-93.438	640
173	35.863	-93.429	625
174	35.863	-93.421	426
175	35.863	-93.413	555
176	35.863	-93.404	612
177	35.871	-93.463	667
178	35.871	-93.454	580
179	35.871	-93.446	656
180	35.871	-93.438	640
181	35.871	-93.429	487
182	35.871	-93.421	457
183	35.871	-93.413	654
184	35.871	-93.404	548
185	35.871	-93.396	622
186 187	35.871	-93.388	683 579
188	35.879 35.879	-93.463	554
		-93.454 -93.446	
189 190	35.879 35.879	-93.446	609 622
190	35.879	-93.438 -93.429	427
191	35.879	-93.429	555
193	35.879	-93.421	502
194	35.879	-93.404	639
195	35.879	-93.404	580
196	35.879	-93.388	639
197	35.888	-93.446	548
198	35.888	-93.438	548
199	35.888	-93.429	438
200	35.888	-93.421	579
201	35.888	-93.404	620
202	35.896	-93.429	579
203	35.896	-93.421	426
204	35.896	-93.413	611
205	35.904	-93.446	604
206	35.904	-93.438	548
207	35.904	-93.429	488
208	35.904	-93.421	402
209	35.904	-93.413	579

Receptor	Latitude	Longitude	Elevation
Receptor	(deg)	(deg)	(m)
210	35.904	-93.404	573
211	35.904	-93.396	609
212	34.371	-94.054	365
213	34.371	-94.046	365
214	34.371	-94.038	368
215	34.379	-94.071	411
216	34.379	-94.063	462
217	34.379	-94.054	431
218	34.379	-94.046	518
219	34.379	-94.038	487
220	34.379	-94.029	396
221	34.388	-94.104	518
222	34.388	-94.096	523
223	34.388	-94.088	548
224	34.388	-94.079	579
225	34.388	-94.071	547
226	34.388	-94.063	538
227	34.388	-94.054	640
228	34.388	-94.046	608
229	34.396	-94.163	335
230	34.396	-94.154	431
231	34.396	-94.146	457
232	34.396	-94.138	414
233	34.396	-94.129	426
234	34.396	-94.121	426
235	34.396	-94.113	388
236	34.396	-94.104	388
237	34.396	-94.096	365
238	34.396	-94.088	386
239	34.396	-94.079	396
240 241	34.396 34.396	-94.071 -94.063	426 446
241	34.396	-94.063	441
243	34.396	-94.034	457
243	34.396	-94.040	465
245	34.396	-94.038	442
246	34.396	-94.029	426
247	34.404	-94.163	304
248	34.404	-94.154	304
249	34.404	-94.146	319
250	34.404	-94.138	334
251	34.404	-94.129	370
252	34.404	-94.121	405
253	34.404	-94.113	409
254	34.404	-94.104	450
255	34.404	-94.096	518
256	34.404	-94.088	609
257	34.404	-94.079	534
258	34.404	-94.071	517
259	34.404	-94.063	575
260	34.404	-94.054	600
261	34.404	-94.046	609
262	34.404	-94.038	609
263	34.404	-94.029	561

Receptor	Latitude	Longitude	Elevation
Receptor	(deg)	(deg)	(m)
264	34.413	-94.154	335
265	34.413	-94.146	432
266	34.413	-94.138	487
267	34.413	-94.129	499
268	34.413	-94.121	514
269	34.413	-94.113	442
270	34.413	-94.104	439
271	34.413	-94.096	395
272	34.413	-94.088	400
273	34.413	-94.079	426
274	34.413	-94.071	487
275	34.413	-94.063	548
276	34.413	-94.054	548
277	34.413	-94.046	548
278	34.413	-94.038	535
279	34.421	-94.146	304
280	34.421	-94.138	334
281	34.421	-94.129	396
282	34.421	-94.121	457
283	34.421	-94.113	457
284	34.421	-94.104	426
285	34.421	-94.096	411
286	34.421	-94.088	406
287	34.421	-94.079	396
288	34.421	-94.071	401
289	34.421	-94.063	397
290 291	34.429	-94.146	322
291	34.429	-94.138	334
292	36.946 36.946	-90.246	106
293	36.954	-90.229 -90.238	102 105
295	36.954	-90.238	103
296	36.954	-90.221	102
297	36.963	-90.238	114
298	36.963	-90.229	104
299	36.963	-90.221	102
300	36.963	-90.213	102
301	36.963	-90.204	102
302	36.963	-90.196	103
303	36.971	-90.229	108
304	36.971	-90.221	105
305	36.971	-90.213	102
306	36.971	-90.204	102
307	36.971	-90.196	102
308	36.971	-90.188	102
309	36.971	-90.179	102
310	36.971	-90.171	102
311	36.979	-90.221	121
312	36.979	-90.213	104
313	36.979	-90.204	102
314	36.979	-90.196	102
315	36.979	-90.188	102
316	36.979	-90.179	102
317	36.979	-90.171	102

Receptor	Latitude	Longitude	Elevation
	(deg)	(deg)	(m)
318	36.988	-90.213	121
319	36.988	-90.204	105
320	36.988	-90.196	102
321	36.988	-90.188	102
322	36.988	-90.179	102
323	36.988	-90.171	101
324	36.996	-90.204	117
325	36.996	-90.196	101
326	36.996	-90.188	101
327	36.996	-90.179	102
328	36.996	-90.171	101
329	37.004	-90.196	106
330	37.004	-90.188	102
331	37.004	-90.179	102
332	37.004	-90.171	102
333	37.013	-90.188	103
334	37.013	-90.179	102
335	37.013	-90.171	102
336	37.021	-90.179	103
337	37.021	-90.171	102
338	37.029	-90.171	103

BART FIVE FACTOR ANALYSIS • KANSAS CITY POWER & LIGHT

LA CYGNE GENERATING STATION

VERSION 0

Prepared by:

Kasi Dubbs • Managing Consultant
Mary Pham • Consultant

TRINITY CONSULTANTS

9777 Ridge Drive Suite 380 Lenexa, Kansas 66219 (913) 894-4500

August 2007

Project 061701.0125



1.		EXECU	TIVE SUMMARY	1-1
2.		INTRO	DUCTION AND BACKGROUND	2-1
	2.1	Presun	MPTIVE LIMITS	2-2
	2.2	Existi	NG CONTROLS	2-3
3.		BART A	APPLICABILITY DETERMINATION	3-1
4.		SO ₂ BA	ART EVALUATION	4-1
	4.1		FICATION OF AVAILABLE RETROFIT SO_2 CONTROL TECHNOLOGIES	
	4.2	ELIMIN	IATE TECHNICALLY INFEASIBLE SO_2 CONTROL TECHNOLOGIES	4-1
		4.2.1	DRY SORBENT INJECTION	
		4.2.2	SPRAY DRYER ABSORPTION (SDA)	4-2
		4.2.3	WET SCRUBBER	4-2
		4.2.4	CIRCULATING DRY SCRUBBER (CDS)	4-2
	4.3	RANK (OF TECHNICALLY FEASIBLE SO_2 CONTROL OPTIONS BY EFFECTIVENESS	4-3
	4.4	EVALU	ATION OF IMPACTS FOR FEASIBLE SO ₂ CONTROLS	4-3
		4.4.1	COST OF COMPLIANCE	4-3
		4.4.2	ENERGY IMPACTS AND NON-AIR QUALITY IMPACTS	4-4
		4.4.3	REMAINING USEFUL LIFE	
	4.5	EVALU	ATION OF VISIBILITY IMPACT OF FEASIBLE SO ₂ CONTROLS	4-4
	4.6	PROPOS	SED BART FOR SO_2	4-5
5.		NO _x B	ART EVALUATION	5-1
	5.1		FICATION OF AVAILABLE RETROFIT NO $_{ m X}$ Control Technologies	
	5.2	ELIMIN	ATE TECHNICALLY INFEASIBLE NO _X CONTROL TECHNOLOGIES	5-2
		5.2.1	COMBUSTION CONTROLS	
			5.2.1.1 Flue Gas Recirculation (FGR)	5-2
			5.2.1.2 Overfire Air (OFA)	5-2
			5.2.1.3 Low and Ultra Low NO _X Burners	5-2
		5.2.2	POST COMBUSTION CONTROLS.	
			5.2.2.1 Selective Catalytic Reduction	5-3
			5.2.2.2 Selective Non-Catalytic Reduction	
	5.3	RANK (OF TECHNICALLY FEASIBLE $\overset{\circ}{\mathrm{NO_{\mathrm{X}}}}$ Control Options by Effectiveness	
	5.4		ATION OF IMPACTS FOR FEASIBLE NO _X CONTROLS	
		5.4.1	COST OF COMPLIANCE	5-5
		5.4.2	ENERGY IMPACTS & NON-AIR IMPACTS	5-9
		5.4.3	REMAINING USEFUL LIFE	
	5.5	EVALU	ATION OF FEASIBLE NO _X CONTROLS IMPACT ON VISIBILITY	
	5.6		SED BART FOR NO _X	

6.	PM BART EVALUATION	6-1
7.	PROPOSED BART LIMITS COMPLIANCE SUMMARY	7-1
7.1	SO ₂ BART COMPLIANCE SUMMARY	7-1
	NO _X BART COMPLIANCE SUMMARY	
7.3	PM ₁₀ BART COMPLIANCE SUMMARY	7-3

TABLE 1-1. VISIBILITY IMPAIRMENT ATTRIBUTABLE TO LA CYGNE GENERATING STATION	. 1-1
Table 1-2. Visibility Impairment Improvement	. 1-2
Table 3-1. Highest Actual 24-Hour SO_2 and NO_X Emissions and Calculated Highest PN Emissions (As an Hourly Equivalent)	
TABLE 3-2. SUMMARY OF STACK PARAMETERS	.3-2
Table 3-3. Summary of 98^{th} Percentile Visibility Impacts and Number of Days with Visibility Impact Greater than $0.5 \Delta \text{dv}$.3-2
TABLE 3-4. Breakdown of Pollutant Specific Contributions to Visibility	.3-2
TABLE 4-1. EXISTING MAXIMUM 24-HOUR SO ₂ EMISSION RATES	.4-1
TABLE 4-2. AVAILABLE SO_2 CONTROL TECHNOLOGIES	.4-1
Table 4-3. Control Effectiveness of Technically Feasible SO_2 Control Technologies	34-3
TABLE 4-4. EXISTING AND PRESUMPTIVE BART EMISSION RATES	.4-5
TABLE 4-5.MODELED IMPACTS BASED ON EXISTING AND PRESUMPTIVE BART EMISSION RATES	.4-5
TABLE 5-1. EXISTING MAXIMUM 24-HOUR NO _X EMISSION RATE	.5-1
Table 5-2. Available NO _x Control Technologies	. 5-1
Table 5-3. Control Effectiveness of Technically Feasible NO_x Control Technologies	s5-5
TABLE 5-4. NO _X Control Technology Cost Factors*	.5-6
TABLE 5-5. NO _x Control Technology Cost Summary (in 2005 Dollars) for La Cygne Un 2	
TABLE 5-6. EXISTING AND PRESUMPTIVE BART EMISSION RATES	.5-9
Table 5-7.Modeled Impacts Based on Existing and Presumptive BART Emission Rates 5	5-10
TABLE 6-1. HISTORICAL MAXIMUM 24-HOUR PM ₁₀ EMISSION RATE	.6-1
Tari e 6-2 Visirii ity Impairment Contributions	6-1

This report documents the determination of the Best Available Retrofit Technology (BART) as proposed by Kansas City Power & Light (KCP&L) for the La Cygne Generating Station located in La Cygne, Kansas. There are two boilers at La Cygne. Unit 1 is an 840 MW supercritical cyclone coal boiler that was manufactured in 1973 by Babcock and Wilcox with a scrubber for sulfur dioxide (SO₂) and particulate matter (PM) control and overfire air that minimizes the formation of thermal nitrogen oxides (NO_X). Unit 2 is a 710 MW radiant opposed-fired pulverized coal (PC) boiler that was manufactured in 1976 by Babcock and Wilcox with an electrostatic precipitator (ESP) for PM control. Unit 1 burns a blend of Powder River Basin (PRB) coal and local coal. Unit 2 burns 100 percent PRB coal.

KCP&L has determined that the two boilers at the La Cygne Generating Station contribute greater than 0.5 deciviews (dv) to visibility impairment in a federally protected Class I area when compared to a natural background. Therefore, these two sources are subject to BART. A summary of the visibility impairment attributable to the boilers is provided in Table 1-1.

TABLE 1-1. VISIBILITY IMPAIRMENT ATTRIBUTABLE TO LA CYGNE GENERATING STATION

	Visibility Impairment			
	98th %	Days > 0.5		
Class I Area	Δdv	Δdv		
Wichita Mountains Wilderness	1.02	57		
Hercules Glades Wilderness	1.74	138		
Caney Creek Wilderness	1.14	63		
Upper Buffalo Wilderness	1.92	125		
Mingo Wilderness	0.92	62		

KCP&L used the guidelines in 40 CFR Part 51¹ to determine BART for the boilers. Specifically, KCP&L conducted a five-step analysis to determine BART for SO₂, NO_X, and PM₁₀ that included the following:

- 1. Identifying all available retrofit control technologies;
- 2. Eliminating technically infeasible control technologies;
- 3. Evaluating the control effectiveness of remaining control technologies;
- 4. Evaluating impacts and document the results;
- 5. Evaluating visibility impacts

Based on the five-step analysis, KCP&L proposes the following as BART:

• NO_X – KCP&L proposes to meet the U.S. Environmental Protection Agency's (EPA's) presumptive BART limits of 0.10 lb/MMBtu and 0.23 lb/MMBtu for Unit 1 and Unit 2, respectively, by complying with a combined Unit 1 and Unit 2 weighted average limit. This

¹ 40 CFR 51, Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations

- will be achieved by operating the currently permitted SCR on Unit 1 and by installing NO_X controls on Unit 2.
- SO₂ KCP&L proposes to meet the U.S. EPA's presumptive BART limit of 0.15 lb/MMBtu for Unit 1 and Unit 2 by complying with a combined Unit 1 and Unit 2 weighted average limit by installing either wet scrubbers or spray dryer absorbers (SDA) on both units.
- PM KCP&L proposes that no additional PM controls are required for BART compliance because the PM controls would provide little visibility improvement while requiring significant capital expenditures. Although not required for BART compliance, KCP&L plans to install baghouses on Unit 1 and Unit 2 for compliance with other environmental regulations.

The proposed presumptive BART emission rates will result in reductions of the visibility impacts attributable to La Cygne Unit 1 and Unit 2. A summary of the visibility improvement based on the existing emission rates and presumptive BART emission rates is provided in Table 1-2.

TABLE 1-2. VISIBILITY IMPAIRMENT IMPROVEMENT

		ney Cre 'ildernes			cules Gla Tildernes		Ming	o Wilde	rness		er Buff ildernes			ta Mour 'ildernes	
	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement
Max Impact (Δdv) 98% Impact	5.16	1.278	75%	4.479	0.998	78%	3.82	0.868	77%	6.359	1.563	75%	8.404	2.117	75%
(Δdv)	1.138	0.227	80%	1.738	0.357	79%	0.915	0.177	81%	1.923	0.415	78%	1.017	0.205	80%
Days > 0.5	63	5	92%	138	6	96%	62	3	95%	125	14	89%	57	7	88%

On July 1, 1999, the U.S. Environmental Protection Agency (EPA) published the final Regional Haze Rule (RHR). The objective of the RHR is to improve visibility in 156 specific areas across with United States, known as Class I areas. The Clean Air Act defines Class I areas as certain national parks (over 6000 acres), wilderness areas (over 5000 acres), national memorial parks (over 5000 acres), and international parks that were in existence on August 7, 1977.

On July 6, 2005, the EPA published amendments to its 1999 RHR, often called the Best Available Retrofit Technology (BART) rule, which included guidance for making source-specific BART determinations. The BART rule defines BART-eligible sources as sources that meet the following criteria:

- (1) Have potential emissions of at least 250 tons per year of a visibility-impairing pollutant,
- (2) Began operation between August 7, 1962 and August 7, 1977, and
- (3) Are included as one of the 26 listed source categories in the guidance.

A BART-eligible source is subject to BART if the source is "reasonably anticipated to cause or contribute to visibility impairment in any federal mandatory Class I area." EPA has determined that a source is reasonably anticipated to cause or contribute to visibility impairment if the 98th percentile visibility impacts from the source are greater than 0.5 deciviews (dv) when compared against a natural background. Air quality modeling is the tool that is used to determine a source's visibility impacts.

Once it is determined that a source is subject to BART, a BART determination must address air pollution control measures for the source. The visibility regulations define BART as follows:

"...an emission limitation based on the degree of reduction achievable through the application of the best system of continuous emission reduction for each pollutant which is emitted by...[a BART-eligible source]. The emission limitation must be established on a case-by-case basis, taking into consideration the technology available, the cost of compliance, the energy and non air quality environmental impacts of compliance, any pollution control equipment in use or in existence at the source, the remaining useful life of the source, and the degree of improvement in visibility which may reasonable be anticipated to result from the use of such technology.

Specifically, the BART rule states that a BART determination should address the following five statutory factors:

- 1. Existing controls
- 2. Cost of controls
- 3. Energy and non-air quality environmental impacts
- 4. Remaining useful life of the source
- 5. Degree of visibility improvement as a result of controls

Further, the BART rule indicates that the five basic steps in a BART analysis can be summarized as follows:

- 1. Identify all available retrofit control technologies;
- 2. Eliminate technically infeasible control technologies;
- 3. Evaluate the control effectiveness of remaining control technologies;
- 4. Evaluate impacts and document the results;
- 5. Evaluate visibility impacts

A BART determination should be made for each visibility affecting pollutant (VAP) by following the five steps listed above for each VAP.

KCP&L performed a BART applicability analysis for La Cygne Unit 1 and Unit 2 and determined the units are subject to BART. The details of the applicability determination can be found in Section 3. Subsequently, KCP&L performed an analysis to determine BART for each VAP for Unit 1 and Unit 2. The VAPs emitted by La Cygne Unit 1 and Unit 2 include NO_x , SO_2 , and particulate matter with a mass mean diameter smaller than ten microns (PM_{10}) of various forms (filterable coarse particulate matter [PM_c], filterable fine particle matter [PM_f], elemental carbon [EC], inorganic condensable particulate matter [PM_c] as sulfates [PM_c], and organic condensable particulate matter [PM_c] also referred to as secondary organic aerosols [PM_c]. The BART determinations for PM_c 0, and PM_c 10 can be found in Sections 4, 5, and 6, respectively.

2.1 Presumptive Limits

EPA established presumptive limits in the BART guidelines for electric generating units (EGUs). The presumptive limits were established by reviewing BART-eligible units and determining a level of emissions reductions that would be cost effective. The EPA's BART guidelines state the following with regard to presumptive BART for SO₂

"You must require 750 MW power plants to meet specific control levels for SO_2 of either 95 percent control or 0.15 lb/MMBtu... For coal fired EGUs with an existing post combustion SO_2 controls achieving less than 50 percent removal efficiencies, we recommend that you evaluate construction a new FGD system to meet the same emission limit as above (95 percent removal or 0.15 lb/MMBtu)"

For power plants greater than 750 MW, EPA requires that state agencies apply the presumptive BART limit as a floor for SO₂. The SO₂ presumptive limit for both Unit 1 and Unit 2 is 0.15 lb/MMBtu.

Similarly for NO_X , the guidelines state:

"For coal-fired EGUs greater than 200 MW located at greater than 750 MW power plants and operating without post-combustion controls (i.e. selective catalytic reduction or selective non-catalytic reduction), we have provided presumptive NO_X limits differentiated by boiler design and type of coal burned."

The guidelines go on to state for cyclone boilers:

"Because of the relatively high NO_X emission rates of cyclone units, SCR is more cost-effective than the use of current combustion control technology for these units. The use of SCRs at cyclone units burning bituminous coal, sub-bituminous coal, and lignite should enable the units to cost-effectively meet NO_X rates of 0.10 lbs/MMBtu.

As a result, we are establishing a presumptive NO_X limit of 0.10 lb/MMBtu based on the use of SCR for coal-fired cyclone units greater than 200 MW located at 750 MW power plants.

Therefore, for units greater than 200 MW located at power plants greater than 750 MW, the presumptive limits are also a floor for NO_X . Since La Cygne Unit 1 is a cyclone boiler, the presumptive limit is 0.10 lb/MMBtu. For La Cygne Unit 2, which is a dry-bottom wall-fired boiler combusting sub-bituminous coal, the NO_X presumptive limit is 0.23 lb/MMBtu.

The BART guidelines do not specify presumptive BART limits for PM₁₀ emissions.

2.2 Existing Controls

La Cygne Unit 1 and Unit 2 have existing emission controls. Unit 1 is currently equipped with a scrubber for SO_2 and particulate control and overfire air that minimizes the formation of thermal NO_X . KCPL is in the process of voluntarily constructing an SCR system for Unit 1 which will further reduce NO_X emissions. The SCR project is scheduled to be operational by May 2007. Unit 2 is equipped with an electrostatic precipitator (ESP) for particulate control.

As stated in Section 2, a BART-eligible source is subject-to-BART if the source is "reasonably anticipated to cause or contribute to visibility impairment in any federal mandatory Class I area." EPA has determined that a source is reasonably anticipated to cause or contribute to visibility impairment if the 98th percentile of the visibility impacts from the source is greater than 0.5 deciviews (dv) when compared against a natural background. KCP&L conducted air quality modeling to predict the existing visibility impairment attributable to La Cygne Unit 1 and Unit 2 in the following Class I areas:

- ▲ Wichita Mountains Wilderness (Fish and Wildlife Service [FWS])
- ▲ Hercules Glades Wilderness (Forest Service [FS])
- ▲ Upper Buffalo Wilderness (FS)
- ▲ Caney Creek Wilderness (FS)
- ▲ Mingo Wilderness (FWS)

The modeling methods and procedures that were followed were provided to the Kansas Department of Health and Environment (KDHE) in a November 2006 modeling protocol. In response to comments provided to KCP&L by KDHE regarding the modeling protocol, the only change made to the modeling methods and procedures documented in the protocol was to correct a typographical error for the November monthly humidity factor for Mingo from 3.4 to the correct value of 3.1. Since this change did not warrant a new version of the protocol, the documentation of this change is provided in this report. Table 3-1 summarizes the emission rates that were modeled for SO₂, NO_x, and PM₁₀, including the speciated PM₁₀ emissions. The SO₂ and NO_x emission rates are the highest actual 24-hour emission rates based on 2002-2004 continuous emissions monitoring system (CEMS) data. The PM₁₀ emission rates are the calculated highest emission rates based on fuel data from 2002-2004 and AP-42 emission factors. The total PM₁₀ emission rates include both the filterable and condensable fractions and are speciated into the following:

- \blacktriangle Coarse particulate matter (PM_C)
- ▲ Fine particulate matter (PM_f)
- ▲ Sulfates (SO₄)
- ▲ Secondary organic aerosols (SOA)
- ▲ Elemental carbon (EC)

TABLE 3-1. HIGHEST ACTUAL 24-HOUR SO_2 AND NO_X EMISSIONS AND CALCULATED HIGHEST PM_{10} EMISSIONS (AS AN HOURLY EQUIVALENT)

	SO ₂	NO_X	Total PM ₁₀	SO_4	PM_c	$PM_{\rm f}$	SOA	EC
	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)
La Cygne - Unit 1	6,151.15	11,589.52	53.79	34.37	4.92	5.68	8.59	0.22
La Cygne - Unit 2	8,316.15	3,543.47	94.92	28.12	33.20	25.58	7.03	0.98

Table 3-2 summarizes the stack parameters that were used to model La Cygne Unit 1 and Unit 2. It should be noted that the good engineering practice (GEP) stack heights were modeled instead of the actual stack heights since the GEP stack heights are less than the actual stack heights.

TABLE 3-2. SUMMARY OF STACK PARAMETERS

	La Cygne Unit 1	La Cygne Unit 2
Latitude (degrees)	38.3486	38.3476
Longitude (degrees)	-94.6456	-94.6456
Actual Stack height (ft)	700	700
GEP Stack height (ft)	591.2	597.8
Stack Diameter (ft)	23	24
Exhaust Velocity (ft/s)	92.7	100.8
Exhaust Temperature (F)	127	281

The results of the modeling indicate that the 98^{th} percentile of the visibility impacts attributable to La Cygne Unit 1 and Unit 2 are greater than 0.5 dv when compared against a natural background. Since the visibility impacts are greater than 0.5 Δ dv, La Cygne Unit 1 and Unit 2 are subject to BART. The results of the modeling are summarized in Table 3-3.

TABLE 3-3. SUMMARY OF 98TH PERCENTILE VISIBILITY IMPACTS AND NUMBER OF DAYS WITH VISIBILITY IMPACT GREATER THAN 0.5 ADV

	Visibility Im	pairment
	98th %	Days > 0.5
Class I Area	Δdv	Δdv
Wichita Mountains Wilderness	1.02	57
Hercules Glades Wilderness	1.74	138
Caney Creek Wilderness	1.14	63
Upper Buffalo Wilderness	1.92	125
Mingo Wilderness	0.92	62

Table 3-4 provides a breakdown of the visibility impacts listed in Table 3-3 by each VAP.

TABLE 3-4. BREAKDOWN OF POLLUTANT SPECIFIC CONTRIBUTIONS TO VISIBILITY

	Visibility Impairment Attributable to SO ₄	Visibility Impairment Attributable to NO ₃	Visibility Impairment Attributable to SOA	Visibility Impairment Attributable to EC	Visibility Impairment Attributable to PM _c	Visibility Impairment Attributable to PM _f	Total Visibility Impairment
Class I Area	(%)	(%)	(%)	(%)	(%)	(%)	(Δdv)
Wichita Mountains Wilderness	82.89	17.02	0.05	0.01	0.01	0.03	1.017
Hercules Glades Wilderness	19.63	79.99	0.20	0.04	0.04	0.10	1.738
Caney Creek Wilderness	24.32	75.46	0.12	0.02	0.02	0.06	1.138
Upper Buffalo Wilderness	20.20	79.53	0.15	0.03	0.02	0.07	1.923
Mingo Wilderness	42.26	57.61	0.07	0.01	0.00	0.03	0.915

As shown in Table 3-4, the most significant contributors to the visibility impairment are sulfates (SO_4) and nitrates (NO_3) . The SO_4 contribution is primarily from the chemical conversion of SO_2 emitted by Unit 1 and Unit 2 to SO_4 ; a very small fraction is from SO_4 emitted as condensable particulate. The NO_3 contribution is entirely from the chemical conversion of NO_X emitted from Unit

1 and Unit 2. The contribution of PM_{10} to the total visibility impairment can be estimated as the sum of the contributions from SOA, EC, PMc, and PMf. The PM_{10} contribution is much smaller (<1%) than the contribution from SO_2 and NO_X .

SO₂ emissions at coal-fired EGUs are the result of the oxidation of the sulfur compounds in the coal during the combustion process.

The existing maximum 24-hour SO₂ emission rates that were modeled for the BART applicability determination are summarized in Table 4-1.

TABLE 4-1. EXISTING MAXIMUM 24-HOUR SO₂ EMISSION RATES

	Maximum 24-	SO_2	SO_2
	Hour Heat	Emission	Emission
	Input	Rate	Rate
	(MMBtu/24hr)	(lb/hr)	(lb/MMBtu)
La Cygne - Unit 1	223,488	6,151.15	0.66
La Cygne - Unit 2	198,911	8,316.15	1.00

4.1 IDENTIFICATION OF AVAILABLE RETROFIT SO₂ CONTROL TECHNOLOGIES

Step 1 of the BART determination is the identification of all available retrofit SO₂ control technologies. A list of control technologies was obtained by reviewing the U.S. EPA's Clean Air Technology Center, control equipment vendor information, publicly-available air permits, applications, and BART analyses, and technical literature published by the U.S. EPA and Regional Planning Organizations (RPOs).

The available retrofit SO₂ control technologies are summarized in Table 4-2.

TABLE 4-2. AVAILABLE SO₂ CONTROL TECHNOLOGIES

SO ₂ Control Technologies
Dry Sorbent Injection Spray Dryer Absorber (SDA) i.e., Semi-Dry Scrubber Wet Scrubber Circulating Dry Scrubber (CDS)

All of the technologies listed in Table 4-2 involve removing the SO_2 in the exhaust gas, which is also known as flue gas desulfurization (FGD).

4.2 ELIMINATE TECHNICALLY INFEASIBLE SO₂ CONTROL TECHNOLOGIES

Step 2 of the BART determination is to eliminate technically infeasible SO_2 control technologies that were identified in Step 1.

4.2.1 DRY SORBENT INJECTION

Dry sorbent injection involves the injection of a lime or limestone powder into the exhaust gas stream where SO₂ becomes entrained in the lime. The stream is then passed through a fabric filter to remove the sorbent and entrained SO₂. The process was developed as a lower cost FGD option because the mixing of the SO₂ and lime occurs directly in the exhaust gas stream instead of in a separate tower. Depending on the residence time and gas stream temperature, sorbent injection control efficiency is typically between 40 and 60 percent.² This control is a technically feasible option for the control of SO₂ from La Cygne Unit 1 and Unit 2.

4.2.2 SPRAY DRYER ABSORPTION (SDA)

Spray dryer absorption is a semi-dry scrubbing system that sprays a fine mist of lime slurry into an absorption tower where the SO_2 is absorbed by the slurry droplets. The absorption of the SO_2 leads to the formation of calcium sulfite and calcium sulfate within the droplets. The liquid-to-gas ratio is such that the heat from the exhaust gas causes the water to evaporate before the droplets reach the bottom of the tower. This leads to the formation of a dry powder which is carried out with the gas and collected with a fabric filter. Existing spray dryer absorption control efficiencies range from 60 to 95 percent.³ This control is a technically feasible option for the control of SO_2 from La Cygne Unit 1 and Unit 2.

4.2.3 WET SCRUBBER

Wet scrubbing involves scrubbing the exhaust gas stream with a slurry comprised of lime or limestone in suspension. The process takes place in a wet scrubbing tower located downstream of a PM control device such as a fabric filter or an ESP to prevent the plugging of spray nozzles and other problems caused by the presence of particulates in the scrubber. Similarly to the chemistry illustrated above for spray dryer absorption, the SO₂ in the gas stream reacts with the lime or limestone slurry to form calcium sulfite and calcium sulfate. Wet lime scrubbing is capable of achieving 80-95 percent control.³ This control is a technically feasible option for the control of SO₂ from La Cygne Unit 1 and Unit 2.

4.2.4 CIRCULATING DRY SCRUBBER (CDS)

In the circulating dry scrubbing process, the flue gas is introduced into the bottom of a reactor vessel at high velocity through a venturi nozzle; the exhaust is mixed with water, hydrated lime, recycled flyash and CDS reaction products. The intensive gas-solid mixing that occurs in the reactor promotes the reaction of sulfur oxides in the flue gas with the dry lime particles. The mixture of reaction products (calcium sulfite/sulfate), unreacted lime, and fly ash is carried out with the exhaust and collected in an ESP or fabric filter. A large portion of the collected particles is recycled to the reactor to sustain the bed and improve lime utilization. CDS absorbers have been installed with both fabric filters and ESPs for particulate control. The control efficiency of a CDS is similar to that of an SDA. This

² "Assessment of Control Technology Options for BART-Eligible Sources: Steam Electric Boilers, Industrial Boilers, Cement Plants and Paper and Pulp Facilities" Northeast States for Coordinated Air Use Management (NESCAUM), March 2005.

³ EPA Module 6: Air Pollutants and Control Techniques

control is a technically feasible option for the control of SO₂ from La Cygne Unit 1 and Unit 2.

4.3 RANK OF TECHNICALLY FEASIBLE SO₂ CONTROL OPTIONS BY EFFECTIVENESS

The third step in the BART analysis is to rank the technically feasible options according to effectiveness. Table 4-3 provides a ranking of the control efficiencies for the controls listed in the previous section.

TABLE 4-3. CONTROL EFFECTIVENESS OF TECHNICALLY FEASIBLE SO₂ CONTROL TECHNOLOGIES

Control Technology	Estimated Control Efficiency
Wet Scrubber	~80-95%
Spray Dryer Absorber (SDA)	~60-95%
Circulating Dry Scrubber (CDS)	~60-95%
Dry Sorbent Injection	~40-60%

As seen in Table 4-3, dry sorbent injection has the lowest estimated control efficiency and will therefore no longer be considered for BART.

It should be noted that Unit 1 has an existing scrubber for SO₂ control; however, the current control efficiency of the scrubber is below the efficiencies for the FGD controls listed in Table 4-3.

4.4 EVALUATION OF IMPACTS FOR FEASIBLE SO₂ CONTROLS

Step four for the BART analysis procedure is the impact analysis. The BART determination guidelines list the four factors to be considered in the impact analysis:

- ▲ Cost of compliance
- ▲ Energy impacts
- ▲ Non-air quality impacts; and
- ▲ The remaining useful life of the source

4.4.1 COST OF COMPLIANCE

The cost of compliance was evaluated for the two technologies with the highest SO_2 control efficiencies: wet scrubbers and SDA systems. The typical annual cost effectiveness for both wet scrubbers and SDA systems is \$200 to \$500 per ton of SO_2 removed at the highest removal efficiencies. The cost effectiveness was estimated from a published cost in a technical paper.⁴ This cost estimate is considered to be study grade, which is +/- 30 percent accuracy.

⁴ "Assessment of Control Technology Options for BART-Eligible Sources: Steam Electric Boilers, Industrial Boilers, Cement Plants and Paper and Pulp Facilities" Northeast States for Coordinated Air Use Management (NESCAUM), March 2005.

In the BART guidelines, EPA calculated that that the majority of BART-eligible units could meet the presumptive limits at a cost of \$400 to \$2,000 per ton of SO₂ removed, based on the use of wet scrubbers and SDA systems. Based on EPA's guidelines as to what is considered cost effective for SO₂ removal and the annual cost effectiveness of \$200 to \$500 published in the technical paper, wet scrubbers and SDA systems are cost effective.

4.4.2 ENERGY IMPACTS AND NON-AIR QUALITY IMPACTS

FGD systems require electricity to operate the blowers and pumps needed for the operation of the scrubbers. The generation of the electricity will most likely involve fuel combustion, which will cause emissions. While the required electricity will result in emissions, the emissions should be small compared to the reduction in SO₂ that would be gained by operating an FGD system.

Wet FGD systems generate wastewater and sludge that must be treated. This places additional burdens on the wastewater treatment and solid waste management capabilities. If wet scrubbing produces calcium sulfite sludge, the sludge will be water-laden, and it must be stabilized for landfilling. If wet scrubbing produces calcium sulfate sludge, it is stable and easy to dewater. However, control costs will be higher because additional equipment is required.

Disposal of material from dry FGD systems is also required and will result in landfill impacts.

4.4.3 REMAINING USEFUL LIFE

The remaining useful life of Unit 1 and Unit 2 do not impact the annualized capital costs because the useful lives of the units are anticipated to be at least as long as the capital cost recovery period, which is 20 years.

4.5 EVALUATION OF VISIBILITY IMPACT OF FEASIBLE SO₂ CONTROLS

The final impact analysis was conducted to assess the visibility improvement for existing emission rates when compared to the presumptive BART emission rates. The existing and presumptive BART emission rates were modeled using CALPUFF. The existing emission rates are the same rates that were modeled for the BART applicability analysis. The BART rates are the presumptive limits (in lb/MMBtu) multiplied by the historical maximum daily heat inputs. A sample calculation of the SO₂ presumptive BART hourly equivalent emission rate for Unit 1 is provided as follows:

$$P * HI * \frac{day}{24hr} = 1,396.8 \text{ lb/hr}$$

Where:

P (Presumptive BART Emission Rate) = 0.15 lb/MMBtu HI (2002-2004 maximum daily heat input) = 223,488 MMBtu/day The existing and presumptive BART emission rates are summarized in Table 4-4.

TABLE 4-4. EXISTING AND PRESUMPTIVE BART EMISSION RATES

	Exis	sting Emission I	Rate	Presumpt	ive BART Emis	ssion Rate
	SO_2	NO_X	PM_{10}	SO_2	NO_X	PM_{10}
	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)
La Cygne - Unit 1	6,151.15	11,589.52	53.79	1,396.80	931.20	53.79
La Cygne - Unit 2	8,316.15	3,543.47	94.92	1,243.19	1,906.23	94.92

The visibility improvement due to the presumptive BART limits was calculated as the difference between the existing visibility impairment and the visibility impairment for the presumptive rates. A comparison of the existing visibility impacts and the visibility impacts based on the presumptive BART emission rates, including the maximum modeled visibility impact, 98^{th} percentile modeled visibility impact, and the number of days with a modeled visibility impact greater than $0.5 \Delta dv$, for each Class I area is provided in Table 4-5. It should be noted that the visibility impacts presented in Table 4-5 are based on the application of the presumptive BART limits for both SO_2 and NO_x . The analysis included the presumptive BART limits from both SO_2 and NO_x in order to determine the overall visibility improvement that would be gained from applying BART to both pollutants. The presumptive BART limits for NO_x are discussed in Section 5.

TABLE 4-5.MODELED IMPACTS BASED ON EXISTING AND PRESUMPTIVE BART EMISSION RATES

		ney Cre ilderne			cules Gl 'ilderne		Ming	o Wilde	rness		oer Buff 'ilderne			ta Mour 'ilderne	
	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement
Max Impact (Δdv)	5.16	1.28	75%	4.48	1.00	78%	3.82	0.87	77%	6.36	1.56	75%	8.40	2.12	75%
98% Impact (Δdv)	1.14	0.23	80%	1.74	0.36	79%	0.92	0.18	81%	1.92	0.42	78%	1.02	0.21	80%
Days > 0.5	63	5	92%	138	6	96%	62	3	95%	125	14	89%	57	7	88%

As seen in Table 4-5, the visibility impacts (the maximum visibility impact, 98^{th} percentile visibility impact, and the number of days with a visibility impact greater than $0.5 \Delta dv$) for each Class I area are lower for the presumptive BART emission rates than for the existing emission rates.

4.6 PROPOSED BART FOR SO₂

KCP&L has determined that the SO₂ BART emission rate for Unit 1 and Unit 2 is the presumptive emission rate of 0.15 lb/MMBtu. KCP&L is proposing to meet the presumptive BART SO₂ emission rate of 0.15 lb/MMBtu for each unit by complying with a combined Unit 1 and Unit 2 weighted average limit. KCP&L will meet this limit by installing scrubbing technology (i.e., either wet scrubber or SDA). Wet scrubbers and SDA systems achieve the highest levels of SO₂ control. In addition, the costs of compliance associated with both controls are similar, so no cost effectiveness is

gained by choosing one control over the other. KCP&L will select one of these control options at a later date pending several factors, including anticipated performance, availability, and market conditions. Performance, availability, and market conditions at the time of the BART implementation may drive the selection of the control option. At that time, a more detailed study may determine that one control is more favorable than the other.

 NO_x from coal-fired EGUs is formed by three fundamentally different mechanisms. The principle NO_x formation mechanism, thermal NO_x , arises from the thermal dissociation and subsequent reaction of nitrogen (N_2) and oxygen (O_2) molecules in the combustion air. Most thermal NO_x forms in the highest temperature regions of the combustion chamber (i.e., the air/fuel interface). The second NO_x formation mechanism, prompt NO_x , arises from early reactions of nitrogen intermediaries and hydrocarbon radicals in the fuel. The final NO_x formation mechanism, fuel NO_x , arises from the evolution and reaction of fuel bound nitrogen compounds with oxygen.

The existing maximum daily NO_X emission rates that were modeled for the BART applicability determination are summarized in Table 5-1.

	Maximum 24- Hour Heat Input (MMBtu/24hr)	NO _X Emission Rate (lb/hr)	NO _X Emission Rate (lb/MMBtu)
La Cygne - Unit 1	223,488	11,589.52	1.24
La Cygne - Unit 2	198,911	3,543.47	0.43

TABLE 5-1. EXISTING MAXIMUM 24-HOUR NO_x EMISSION RATE

5.1 IDENTIFICATION OF AVAILABLE RETROFIT NO_X CONTROL TECHNOLOGIES

Step 1 of the BART determination is the identification of all available retrofit NO_X control technologies. A list of control technologies was obtained by reviewing the U.S. EPA's Clean Air Technology Center, control equipment vendor information, publicly-available air permits, applications, and BART analyses, and technical literature published by the U.S. EPA and the RPOs.

The available retrofit NO_x control technologies are summarized in Table 5-2.

TABLE 5-2. AVAILABLE NO_X CONTROL TECHNOLOGIES

	NO _X Control Technologies
	Flue Gas Recirculation (FGR)
Combustion Controls	Overfire Air (OFA)
	Low NO _X Burners (LNB) and Ultra Low NO _X Burners (ULNB)
Post-Combustion Controls	Selective Catalytic Reduction (SCR)
1 ost-Comoustion Controls	Selective Non-Catalytic Reduction (SNCR)

 NO_X emissions controls, as listed in Table 5-2, can be categorized as combustion or post-combustion controls. Combustion controls, including flue gas recirculation (FGR), overfire air (OFA), and Low

 NO_X Burners (LNB), reduce the peak flame temperature and excess air in the furnace which minimizes NO_X formation. Post-combustion controls, such as selective catalytic reduction (SCR) and selective non-catalytic reduction (SNCR) convert NO_X in the flue gas to molecular nitrogen and water.

5.2 ELIMINATE TECHNICALLY INFEASIBLE NO_x Control Technologies

Step 2 of the BART determination is to eliminate technically infeasible NO_X control technologies that were identified in Step 1.

5.2.1 COMBUSTION CONTROLS

5.2.1.1 FLUE GAS RECIRCULATION (FGR)

FGR uses flue gas as an inert material to reduce flame temperatures. In a typical flue gas recirculation system, flue gas is collected from the heater or stack and returned to the burner via a duct and blower. The addition of flue gas reduces the oxygen content of the "combustion air" (air + flue gas) in the burner. The lower oxygen level in the combustion zone reduces flame temperatures; which in turn reduces thermal NO_X formation. When operated without additional controls, the NO_X control efficiency range for FGR is 30 percent to 50 percent. When coupled with LNB the control efficiency increases to 50-72 percent.⁵ This control is a technically feasible option for the control of NO_X from La Cygne Unit 1 and Unit 2.

5.2.1.2 OVERFIRE AIR (OFA)

OFA diverts a portion of the total combustion air from the burners and injects it through separate air ports above the top level of burners. Staging of the combustion air creates an initial fuel-rich combustion zone with a lower peak flame temperature. This reduces the formation of thermal NO_X by lowering combustion temperature and limiting the availability of oxygen in the combustion zone where NO_X is most likely to be formed.

OFA as a single NO_X control technique may reduce NO_X emissions by 25 to 55 percent. When combined with LNB, reductions of up to 60 percent may result.⁶ KCP&L currently uses OFA on La Cygne Unit 1, and this is a technically feasible option for the control of NO_X from La Cygne Unit 2.

5.2.1.3 LOW AND ULTRA LOW NO_X BURNERS

LNB technology utilizes advanced burner design to reduce NO_X formation through the restriction of oxygen, lowering of flame temperature, and/or reduced residence time. LNB is a staged combustion process that is designed to

⁵ "Midwest Regional Planning Organization Boiler Best Available Retrofit Technology (BART) Engineering Analysis" MACTEC, March 30, 2005.

^{6 &}quot;Assessment of Control Technology Options for BART-Eligible Sources: Steam Electric Boilers, Industrial Boilers, Cement Plants and Paper and Pulp Facilities" Northeast States for Coordinated Air Use Management (NESCAUM), March 2005

split fuel combustion into two zones. In the primary zone, NO_X formation is limited by either one of two methods. Under staged fuel-rich conditions, low oxygen levels limit flame temperatures resulting in less NO_X formation. The primary zone is then followed by a secondary zone in which the incomplete combustion products formed in the primary zone act as reducing agents. Alternatively, under staged fuel-lean conditions, excess air will reduce flame temperature to reduce NO_X formation. In the secondary zone, combustion products formed in the primary zone act to lower the local oxygen concentration, resulting in a decrease in NO_X formation. The estimated NO_X control efficiency for LNBs in high temperature applications is 25 percent. However when coupled with FGR or SNCR these efficiencies increase to 50-72 and 50-89 percent, respectively.

ULNBs may incorporate a variety of techniques including induced FGR, steam injection, or a combination of techniques. These burners combine the benefits of flue gas recirculation and LNB control technologies. Rather than a system of fans and blowers (like FGR), the burner is designed to recirculate hot, oxygen depleted flue gas from the flame or firebox back into the combustion zone. This leads to a reduction in the average oxygen concentration in the flame without reducing the flame temperature below temperatures necessary for optimal combustion efficiency.

The estimated NO_X control efficiency for ULNBs in high temperature applications is 50 percent. Newer designs have yielded efficiencies of between 75-85 percent. When coupled with SCR, efficiencies in the range of 85-97 percent can be obtained.⁸

LNBs and ULNBs are technically feasible for tangential and wall-fired boilers of various sizes, but are not feasible for other boiler types such as cyclone or stoker. 9 Since La Cygne Unit 1 is a cyclone boiler, LNBs and ULNBs are not technically feasible for the control of NO_x from this boiler. LNBs and ULNBs are technically feasible for the control of NO_x from La Cygne Unit 2.

5.2.2 Post Combustion Controls

 NO_X can be reduced to molecular nitrogen (N_2) in add-on systems located downstream of the furnace. The two main post-combustion control techniques in commercial service are SCR and SNCR.

5.2.2.1 SELECTIVE CATALYTIC REDUCTION

SCR refers to the process in which NO_x is reduced by ammonia over a heterogeneous catalyst in the presence of oxygen. The process is termed

⁷ "Midwest Regional Planning Organization Boiler Best Available Retrofit Technology (BART) Engineering Analysis" MACTEC, March 30, 2005.

 $^{^8}$ Interim White Paper "Source Category: Electric Generating Units" Midwest RPO Candidate Control Measures, December 9, 2005

⁹ AP 42, Fifth Edition, Volume I Chapter 1 Section 1.1.4.3

selective because the ammonia preferentially reacts with NO_X rather than oxygen, although the oxygen enhances the reaction and is a necessary component of the process. The overall reactions can be written:

$$4NO + 4NH_3 + O_2$$
 \rightarrow $4N_2 + 6H_2O$
 $2NO_2 + 4NH_3 + O_2$ \rightarrow $3N_2 + 6H_2O$

The SCR process requires a reactor, a catalyst, and an ammonia storage and injection system. The effectiveness of an SCR system is dependent on a variety of factors, including the inlet NO_x concentration, the exhaust temperature, the ammonia injection rate, and the type of catalyst. The NO_x control efficiency range for SCR is 70 to 90 percent. ¹⁰ This control is a technically feasible option for the control of NO_x from La Cygne Unit 1 and Unit 2.

5.2.2.2 SELECTIVE NON-CATALYTIC REDUCTION

In SNCR systems, a reagent is injected into the flue gas in the furnace within an appropriate temperature window. The NO_x and reagent (ammonia or urea) react to form nitrogen and water. A typical SNCR system consists of reagent storage, multi-level reagent-injection equipment, and associated control instrumentation. The SNCR reagent storage and handling systems are similar to those for SCR systems. However, because of higher stoichiometric ratios, both ammonia and urea SNCR processes require three or four times as much reagent as SCR systems to achieve similar NO_x reductions. The NO_x control efficiency range for SNCR is 25 to 50 percent. This control is a technically feasible option for the control of NO_x from La Cygne Unit 1 and Unit 2.

5.3 RANK OF TECHNICALLY FEASIBLE NO_X CONTROL OPTIONS BY EFFECTIVENESS

The third step in the BART analysis is to rank the technically feasible options according to effectiveness.

¹⁰ Ibid.

¹¹ Interim White Paper "Source Category: Electric Generating Units" Midwest RPO Candidate Control Measures, December 9, 2005.

Table 5-3. Control Effectiveness of Technically Feasible NO_x Control Technologies

Control Technology	Estimated Control Efficiency (%)
SCR	~70-90
OFA/LNB*	~30-60
LNB*	~25-50
FGR	~30-50
SNCR	~25-50
OFA	~25-55

^{*}LNBs are technically feasible for La Cygne Unit 2 only, they are not technically feasible for La Cygne Unit 1.

5.4 EVALUATION OF IMPACTS FOR FEASIBLE NO_x CONTROLS

Step four for the BART analysis procedure is the impact analysis. The BART determination guidelines list four factors to be considered in the impact analysis:

- ▲ Cost of compliance
- ▲ Energy impacts
- ▲ Non-air quality impacts; and
- ▲ The remaining useful life of the source

5.4.1 COST OF COMPLIANCE

Control Costs

The capital costs, operating costs, and cost effectiveness for combustion controls and SCR were estimated for La Cygne Unit 2 using an EPA cost estimate method outlined in the document *Nitrogen Oxides* (NO_X), Why and How They Are Controlled. ¹² These control options were selected because they provide the highest levels of control and are commonly used for NO_X control in large utility boilers. For the purposes of this analysis, LNB with OFA was used to represent a combustion controls system capable of achieving a NO_X emission rate of 0.23 lb/MMBtu.

The EPA cost method relies on cost factors for capital costs, annual fixed operating and maintenance costs, and annual variable operating and maintenance costs for each of the control technologies. A summary of the cost factors is provided in Table 5-4.

¹² Nitrogen Oxides (NO_X), Why and How They Are Controlled. EPA 456/F-99-006R, November 1999.

TABLE 5-4. NO_X CONTROL TECHNOLOGY COST FACTORS*

Control	Capacity	Capital	Fixed	Variable	Capital Cost	Annualized	Annual Fixed	Annual	Total
Technology	(MW) Cost	Cost	O&M	O&M	(\$)	Capital	O&M Cost		Annual
		(\$/kW)	(\$/kW/yr)	(mils/kWh)		$Cost^{**}$	(\$/yr)	O&M Cost	Cost
						(\$/yr)		(\$/yr)	(\$/yr)
Combustion									
Controls System [§]	750	22.8	0.35	0.07	17,100,000	2,008,566	262,500	459,900	2,730,966
SCR	750	69.7	6.12	0.24	52,275,000	6,140,222	4,590,000	1,576,800	12,307,022

*These cost factors are in 1997 dollars. Table 5-5 shows the capital costs, annual fixed O&M costs, and annual variable O&M costs in 2005 dollars.

**The annualized cost is based on a recovery period of 20 years, assuming 10% interest. The capital recovery factor (CRF) of 0.11746 was obtained from EPA's Air Pollution Control Cost Manual, Sixth Edition. EPA 452/B-02-001, January 2002.

[§]For the purposes of this analysis, the cost of a combustion control system is represented by a LNB w/OFA system capable of achieving a NO_x emission rate of 0.23 lb/MMBtu. As KCP&L is proposing not to commit to specific combustion controls at this time, KCP&L is using LNB w/ OFA to represent combustion control equipment that can achieve a NO_x rate of 0.23 lb/MMBtu.

These cost estimates are considered to be study grade, which is +/- 30 percent accuracy. It is likely that these costs are low, since the costs may not reflect the current high market price for steel and other increased costs associated with high demand.

KCP&L is in the process of constructing an SCR system on La Cygne Unit 1. Since SCR provides the highest level of control there is no need to evaluate the cost for other controls. Construction on the SCR system is scheduled to be operational in May 2007.

Annual Tons Reduced

The annual tons reduced that were used in the cost effectiveness calculations for NO_X controls on La Cygne Unit 2 were estimated by subtracting the estimated controlled annual emission rates from the existing annual emission rates. The existing annual emission rates were the highest 365-day rolling totals as determined from CEMS data from 2002-2004.

The controlled annual emission rates were estimated based on the controlled NO_X emission rates for each control method in lb/MMBtu. These emission rates were multiplied by the maximum 365-day rolling heat input as determined from CEMS data from 2002-2004.

A sample of the controlled annual emission rate is provided below for combustion controls with a controlled emission rate of 0.23 lb/MMBtu:

 $0.23lb / MMBtu \times 63,507,314MMBtu / yr \div 2,000lb / ton = 7,303 tpy$

Cost Effectiveness

The capital costs were annualized over a 20-year period and then added to the annual operating costs to obtain the total annualized costs for each technology. The cost effectiveness for a combustion controls system (represented by LNB with OFA) and SCR were determined by dividing the total annualized cost by the annual tons reduced. The control technology costs are summarized for Unit 2 in Table 5-5.

In the BART guidelines, EPA calculated that for all types of boilers other than cyclone boilers, combustion control technology is generally more cost-effective than post-combustion controls. EPA estimates that approximately 75 percent of the BART units (non-cyclone) could meet the presumptive NO_X limits at a cost of \$100 to \$1,000 per ton of NO_X removed based on the use of combustion control technology. For the units that could not meet the presumptive limits using combustion control technology, EPA estimates that almost all of these sources could meet the presumptive limits using advanced combustion controls; the EPA estimates that the cost of such controls are usually less than \$1,500 per ton removed.

Table 5-5 indicates that the cost effectiveness of a combustion controls system (represented by LNB with OFA) for La Cygne Unit 2 is less than \$1,500 per ton of NO_X removed; however, the cost for SCR is over \$1500 per ton of NO_X removed, which is greater than EPA's cost estimate for advanced combustion controls.

Table 5-5. ${\rm NO_X}$ Control Technology Cost Summary (in 2005 Dollars) for La Cygne Unit 2

	Current Annual Emission	Estimated Controlled Emissions	itrolled	Annual Emissions	Capital	Annualized Fixed	Annualized Annualized Fixed Variable	Total Annualized	Cost
	Natio	Limbsion	vaic	Wednesd	1600	OCCIVI	OCCIM	1600	Lilocuvonos
	(tpy)	(lb/MMBtu)	(tpy)	(ton/yr)	(\$)	(\$/yr)	(\$/yr)	(\$/yr)	(\$/ton)
Combustion									
Controls System**	10,669	0.23	7,303	3,365	3,365 20,714,670 317,988	317,988	557,116	557,116 3,308,249	983
SCR	10,669	0.10	3,175	7,493	63,325,110	7,493 63,325,110 5,560,254 1,910,111 14,908,532	1,910,111	14,908,532	1,990

*The costs are annualized in 2005 dollars.

** For the purposes of this analysis, the cost of a combustion control system is represented by a LNB w/OFA system capable of achieving a NO_x emission rate of 0.23 lb/MMBtu.

5.4.2 ENERGY IMPACTS & NON-AIR IMPACTS

SCR systems require electricity to operate the blowers and pumps needed to operate the systems. The generation of the electricity will most likely involve fuel combustion, which will cause emissions. While the required electricity will result in the emissions, the emissions should be small compared to the reduction in NO_x that would be gained by operating an SCR system

SCR can potentially cause significant environmental impacts related to the usage and storage of ammonia. Storage of aqueous ammonia above 10,000 lbs is regulated by a risk management program (RMP), since the accidental release of ammonia has the potential to cause serious injury and death to persons in the vicinity of the release. Ammonia can also be emitted in the exhaust of boilers that operate with SCR or SNCR for NO_X control due to ammonia slip.

Ammonia slip from SCR and SNCR systems occurs either from ammonia injection at temperatures too low for effective reaction with NO_x , leading to an excess of unreacted ammonia, or from over-injection of reagent leading to uneven distribution; which also leads to an excess of unreacted ammonia. Ammonia released from SCR and SNCR systems will react with sulfates and nitrates in the atmosphere to form ammonium sulfate. Together, ammonium sulfate and ammonium nitrate are the predominant sources of regional haze.

5.4.3 REMAINING USEFUL LIFE

The remaining useful life of Unit 1 and Unit 2 do not impact the annualized capital costs of potential controls because the useful lives of the units are anticipated to be at least as long as the capital cost recovery period, which is 20 years.

5.5 EVALUATION OF FEASIBLE NO_x CONTROLS IMPACT ON VISIBILITY

The final impact analysis was conducted to assess the visibility improvement for existing emission rates when compared to the presumptive BART emission rates. The existing and presumptive BART emission levels were modeled using CALPUFF. The existing emission rates are the same rates that were modeled for the BART applicability analysis. The BART rates are the presumptive limits (in lb/MMBtu) multiplied by the historical maximum daily heat inputs. The existing and BART emission rates are summarized in Table 5-6.

TABLE 5-6. EXISTING AND PRESUMPTIVE BART EMISSION RATES

	Exis	sting Emission I	Rate	Presumptive BART Emission Rate				
	SO_2	NO_X	PM_{10}	SO_2	NO_X	PM_{10}		
	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)		
La Cygne - Unit 1	6,151.15	11,589.52	53.79	1,396.80	931.20	53.79		
La Cygne - Unit 2	8,316.15	3,543.47	94.92	1,243.19	1,906.23	94.92		

The visibility improvement due to the presumptive BART limits was calculated as the difference between the existing visibility impairment and the visibility impairment for the presumptive rates. A comparison of the existing visibility impacts and the visibility impacts based on the presumptive BART emission rates, including the maximum modeled visibility impact, 98^{th} percentile modeled visibility impact, and the modeled number of days with a modeled visibility impact greater than 0.5 Δdv , for each Class I area is provided in Table 5-7. It should be noted that the visibility impacts presented in Table 5-7 are based on the application of the presumptive BART limits for both SO_2 and NO_x . The analysis included the presumptive BART limits from both SO_2 and NO_X in order to determine the overall visibility improvement that would be gained from applying BART to both pollutants. The presumptive BART limits for SO_2 are discussed in Section 4.

TABLE 5-7.MODELED IMPACTS BASED ON EXISTING AND PRESUMPTIVE BART EMISSION RATES

		ney Cre ilderne			cules Gla Tilderne		Ming	o Wilde	rness		oer Buff Ilderne			ta Mou 'ilderne	
	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement	Existing	BART	Improvement
Max Impact (Δdv)	5.16	1.28	75%	4.48	1.00	78%	3.82	0.87	77%	6.36	1.56	75%	8.40	2.12	75%
98% Impact	3.10	1.20	1370	7.70	1.00	7070	3.02	0.07	7770	0.30	1.50	1370	0.40	2,12	1370
(Δdv)	1.14	0.23	80%	1.74	0.36	79%	0.92	0.18	81%	1.92	0.42	78%	1.02	0.21	80%
Days > 0.5	63	5	92%	138	6	96%	62	3	95%	125	14	89%	57	7	88%

As seen in Table 5-6, the visibility impacts (the maximum visibility impact, 98^{th} percentile visibility impact, and the number of days with a visibility impact greater than $0.5 \, \Delta dv$) for each Class I area are lower for the presumptive BART emission rates than for the existing emission rates.

5.6 PROPOSED BART FOR NO_X

KCP&L has determined that the NO_X BART emission rates are the presumptive emission rates of 0.10 lb/MMBtu and 0.23 lb/MMBtu for Unit 1 and Unit 2, respectively. The presumptive NO_X limit of 0.10 lb/MMBtu for cyclone units is based on the use of SCR and the NO_X limit of 0.23 lb/MMBtu is based on combustion controls. Therefore, KCP&L proposes that the currently permitted SCR is equivalent to BART controls for Unit 1 and that combustion controls, such as LNB or LNB and OFA, or post-combustion controls, such as an SCR, are equivalent to BART controls for Unit 2.

Although KCP&L proposes that combustion controls are equivalent to BART for Unit 2, KCP&L proposes to install an SCR for Unit 2 and further study the installation of combustion controls on Unit 2. KCP&L will further study combustion control options at a later date pending several factors, including other regulatory requirements, availability, and market conditions. The concerns surrounding these factors are described below.

La Cygne Generating Station is located just south of the Kansas City metropolitan area. Based on ozone monitoring data for the past several ozone seasons, KCP&L anticipates that the Kansas City metropolitan area may soon implement regulatory requirements to reduce volatile organic compound (VOC) and NO_x emissions in the area in order to avoid designation as a nonattainment area for the

ozone National Ambient Air Quality Standard (NAAQS). Controls at La Cygne Generating Station have already been proposed as part of the Kansas City Ozone Maintenance Plan, which has been submitted and approved by EPA. This may require KCP&L to install NO_X controls sooner than the BART deadline for controls implementation. The extent of NO_X reductions and the exact timeline for implementation that would be required are unknown at this time. KCP&L would like to retain the flexibility to choose a control option based on upcoming ozone standard regulatory requirements that may require additional NO_X controls prior to the BART deadline.

Lastly, market conditions and vendor availability at the time of the BART implementation may drive the selection of combustion control options. At that time, a more detailed study analysis may determine that one combustion control is more favorable than the other.

Additional details on the proposed compliance demonstration methods are provided in Section 7.

The primary source of PM from Unit 1 and Unit 2 is the fly ash in the flue gas. Other sources of PM include unburned carbon present in the flue gas, which is the result of incomplete combustion, and reactions of SO_2 and NO_X compounds to form fine PM in the form of nitrates, sulfur trioxide, sulfates, and sulfuric acid mist.

The maximum daily PM₁₀ emission rates that were modeled for the BART applicability determination are summarized in Table 6-1.

	Maximum 24- Hour Heat Input (MMBtu/24hr)	PM ₁₀ Emission Rate (lb/hr)	PM ₁₀ Emission Rate (lb/MMBtu)
La Cygne - Unit 1	223,488	53.79	0.006
La Cygne - Unit 2	198,911	94.92	0.011

TABLE 6-1. HISTORICAL MAXIMUM 24-HOUR PM₁₀ EMISSION RATE

From Table 6-1 it can be seen that the current PM_{10} emission rates for Unit 1 and Unit 2 are much less than the current emission rates of SO_2 and NO_X . The low PM_{10} emission rates correspond to very low visibility impacts attributable to PM_{10} when compared to the impacts attributable to SO_2 and NO_X , as shown in Table 6-2.

TABLE 6-2. \(\)	VISIBILITY	IMPAIRMENT	CONTRIBUTIONS

Year	Visibility	Visibility	Visibility
	Impairment	Impairment	Impairment
	Attributable to	Attributable to	Attributable to
	$\mathrm{SO_4}^1$	NO_3^2	PM_{10}^{2}
	(%)	(%)	(%)
Wichita Mountains	82.89	17.02	0.10
Hercules Glades	19.63	79.99	0.38
Caney Creek	24.32	75.46	0.22
Upper Buffalo	20.20	79.53	0.27
Mingo Wildlife	42.26	57.61	0.11

¹ The visibility impairment attributable to SO_4 is primarily from SO_2 emissions. A very small portion is from SO_4 emitted as condensable particulate.

Given the small PM_{10} emission rates compared to SO_2 and NO_X and the small contribution of PM_{10} to the visibility impacts, any additional control technology would provide little visibility improvement and require significant capital expenditures. Therefore, additional control technologies would not be cost effective, and are not required as PM control technologies for BART compliance. Although not

² The visibility impairment attributable to NO₃ is entirely from NO_X emissions.

³ The visibility impairment attributable to PM_{10} is the sum of the visibility impairment attributable to all modeled primary PM species (PMc, PMf, EC, and SOA).

7.1 SO₂ BART COMPLIANCE SUMMARY

Based on the SO₂ BART analysis, KCP&L has determined that the BART limit for SO₂ for Unit 1 and Unit 2 is the presumptive emission limit of 0.15 lb/MMBtu. Per the BART guidelines, states may allow sources to "average" emissions across any set of BART-eligible emission units within a fenceline, so long as the emission reductions from each pollutant being controlled for BART would be equal to those reductions that would be obtained by simply controlling each of the BART-eligible units that constitute a BART-eligible source. The weighted average of the BART limits for Unit 1 and Unit 2 is 0.15 lbs/MMBtu.

Even though the weighted average of the presumptive BART limits for Unit 1 and Unit 2 is 0.15 lb/MMBtu, KCP&L proposes to demonstrate compliance with a limit that is more stringent than this limit. Specifically, KCP&L proposes a weighted average limit of 0.10 lb/MMBtu on a 30-day rolling average for Unit 1 and Unit 2. The proposed weighted average emission limit is below the presumptive BART emission rates which will result in reductions of the visibility impacts attributable to La Cygne Unit 1 and Unit 2 in excess of those indicated in Sections 4 and 5.

KCP&L proposes to demonstrate compliance with the Unit 1 and Unit 2 weighted average emission limit of 0.10 lbs/MMBtu using the existing CEMS with a new 30-day rolling average report. The CEMS software will be configured to generate a two unit weighted average. The daily average SO₂ rate for each unit will be the average of the hourly SO₂ rates for each hour of a particular boiler operating day, excluding periods of start-up and shut-down. A boiler operating day will be any day that the unit combusts fuel for any period of time, excluding periods of start-up and shut-down. The two-unit daily average will be calculated using the following equation:

$$\frac{((SO_{2Day\#1} \times HI_{sum-day\#1}) + (SO_{2Day\#2} \times HI_{sum-day\#2}))}{(HI_{sum-day\#1} + HI_{sum-day\#2})}$$

Where:

 $SO_{2\text{day}\#1}$ = Daily average of hourly SO_2 rates for Unit 1

 $SO_2 \frac{dav}{dav} = Daily$ average of hourly SO_2 rates for Unit 2

 $HI_{sum-day#1} = Summation of hourly heat inputs for the day for Unit 1$

 $HI_{sum-day\#2} = Summation of hourly heat inputs for the day for Unit 2$

The 30-day rolling average will be the simple average of the last 30 days of two-unit daily averages and will be in compliance if it is less than 0.10 lbs/MMBtu, excluding periods of start-up and shut-down.

Periods of start-up and shut-down for Unit 1 and Unit 2 will be based on good industry practice or the manufacturer's recommendations.

7.2 NO_X BART COMPLIANCE SUMMARY

Based on the NO_X BART analysis, KCP&L has determined that the BART limits for NO_X are the presumptive emission limits of 0.10 lb/MMBtu and 0.23 lb/MMBtu for Unit 1 and Unit 2, respectively. Per the BART guidelines, states may allow sources to "average" emissions across any set of BART-eligible emission units within a fenceline, so long as the emission reductions from each pollutant being controlled for BART would be equal to those reductions that would be obtained by simply controlling each of the BART-eligible units that constitute a BART-eligible source. The weighted average of the presumptive BART limits for Unit 1 and Unit 2 is 0.16 lbs/MMBtu. The Unit 1 + Unit 2 weighted average emission limit has been calculated as follows:

$$\frac{\sum_{i=1}^{2} R_{ip} \times HI_{im}}{\sum_{i}^{2} HI_{im}}$$

Where

 R_{ip} = Presumptive BART emission rate for unit i (lb/MMBtu)

 HI_{im} = Maximum daily heat input from 2002-2004 (MMBtu/day) for unit i

The detailed calculation of the weighted presumptive emission limit is shown below.

$$\frac{\left(R_{1p} \times HI_{1m}\right) + \left(R_{2p} \times HI_{2m}\right)}{\left(HI_{1m} + HI_{2m}\right)} = 0.16 \text{ lb/MMBtu}$$

Where:

 R_{1p} = Presumptive BART emission rate for Unit 1 (lb/MMBtu) = 0.10 lb/MMBtu HI_{1m} = Maximum daily heat input from 2002-2004 (MMBtu/day) for Unit 1 = 223,488 MMBtu/day

 $R_{\rm 2p}$ = Presumptive BART emission rate for Unit 2 (lb/MMBtu) = 0.23 lb/MMBtu HI $_{\rm 2m}$ = Maximum daily heat input from 2002-2004 (MMBtu/day) for Unit 2 = 198,911 MMBtu/day

Even though the weighted average of the presumptive BART limits for Unit 1 and Unit 2 is 0.16 lb/MMBtu, KCP&L proposes to demonstrate compliance with a limit that is more stringent than this limit. Specifically, KCP&L proposes a weighted average limit of 0.13 lb/MMBtu on a 30-day rolling average for Unit 1 and Unit 2. The proposed weighted average emission limit is below the presumptive BART emission rates which will result in reductions of the visibility impacts attributable to La Cygne Unit 1 and Unit 2 in excess of those indicated in Sections 4 and 5.

KCP&L proposes to demonstrate compliance with the Unit 1 and Unit 2 weighted average emission limit of 0.13 lbs/MMBtu using the existing CEMS with a new 30-day rolling average report. The CEMS software will be configured to generate a two unit weighted average. The daily average NO_X rate for each unit will be the average of the hourly NO_X rates for each hour of a particular boiler

operating day, excluding periods of start-up and shut-down. A boiler operating day will be any day that the unit combusts fuel for any period of time, excluding periods of start-up and shut-down. The two-unit daily average will be calculated using the following equation:

$$\frac{((NO_{xDay\#1} \times HI_{sum-day\#1}) + (NO_{xDay\#2} \times HI_{sum-day\#2}))}{(HI_{sum-day\#1} + HI_{sum-day\#2})}$$

Where:

 $NO_{Xday\#1}$ = Daily average of hourly NO_X rates for Unit 1

 $NO_{X \text{ day#2}} = Daily$ average of hourly NO_{X} rates for Unit 2

 $HI_{sum-day#1} = Summation of hourly heat inputs for the day for Unit 1$

 $HI_{sum-day\#2} = Summation of hourly heat inputs for the day for Unit 2$

The 30-day rolling average will be the simple average of the last 30 days of two-unit daily averages and will be in compliance if it is less than 0.13 lbs/MMBtu, excluding periods of start-up and shutdown.

In the event of an extraordinary situation involving an extended outage of Unit 2 (duration in excess of 10 weeks) KCP&L will submit a plan to KDHE to achieve compliance with a La Cygne Unit 1 NO_x presumptive limit of 0.10 lbs/MMBtu on a 30-day rolling average excluding periods of start-up and shut-down. The 10-week period is intended to cover all anticipated scheduled outages so that this scenario would only come up in the case of a unit retirement or a catastrophic loss of one unit.

Periods of start-up and shut-down for Unit 1 and Unit 2 will be based on good industry practice or the manufacturer's recommendations.

7.3 PM₁₀ BART COMPLIANCE SUMMARY

KCP&L proposes that no additional PM controls are required for BART compliance. Although not required for BART compliance, KCP&L plans to install a baghouse on Unit 1 and Unit 2 for compliance with other environmental regulations.

KCP&L proposes to demonstrate compliance with the La Cygne Unit 1 and Unit 2 average emission limit of 0.015 lbs/MMBtu for PM_{10} (filterable) and 0.024 lbs/MMBtu for PM_{10} (total) by conducting annual stack tests. Compliance is demonstrated if the weighted average stack test results of the two units combined meets the emission limits. Annual stack test results will be the average of three one-hour stack tests for each unit.